



STATE OF WASHINGTON

## STATE BUILDING CODE COUNCIL

906 Columbia Street SW • P.O. Box 48300 • Olympia, Washington 98504-2525 • (360) 725-2967

### STATE BUILDING CODE INTERPRETATION NO. 00-06

**CODE:** 1997 Uniform Plumbing Code (UPC)

**SECTION:** WAC 51-46-0301, Section 301—Materials – Standards and Alternates

**QUESTIONS:** Section 301.1.1 of the 1997 Uniform Plumbing Code, as amended by the State of Washington (WAC 51-46-0301), states that materials and fixtures “shall conform to approved nationally recognized standards” and “shall be listed or labeled by a listing agency or shall be approved by the Administrative Authority”.

1. Does the Washington State Building Code Council maintain a list of acceptable listing agencies referred to in WAC 51-46-0301?

2. Would IAPMO Research and Testing, Underwriters Laboratories Inc., or any other nationally recognized testing laboratory be an acceptable listing agency for products manufactured, listed and labeled to applicable standards enumerated in Table 14-1 Referenced Standards?

**ANSWERS:** 1. No.

2. Yes.

**SUPERSEDES:** None

**REQUESTED BY:** Snohomish County

June 2000