



Washington State Building Code Council

Improving the built environment by promoting health, safety and welfare

1500 Jefferson Street SE • P.O. Box 41449 • Olympia, Washington 98504
(360) 407-9280 • fax (360) 586-5366 • e-mail sbcc@ga.wa.gov • www.ga.wa.gov/sbcc

STATE BUILDING CODE INTERPRETATION NO. 14-11

- CODE:** 2012 Washington State Energy Code, Commercial
- SECTION:** Table C407.5.1, Specifications for standard reference & proposed designs
- QUESTION:** When following the total building performance method of compliance, Table C407.5.1(1) specifies that “On-site renewable energy sources energy shall not be considered to be consumed energy and shall not be included in the proposed building performance.” Is the intent of the code to take the projected production of the on-site renewable energy systems and deduct it from the net annual energy consumption of the proposed design?
- ANSWER:** Yes.
- SUPERSEDES:** None
- REQUESTED BY:** MVE Committee; based on proposal Log No. 14-E16