



## **Washington State Building Code Council**

*Improving the built environment by promoting health, safety and welfare*

1500 Jefferson Street SE • P.O. Box 41449 • Olympia, Washington 98504  
(360) 407-9280 • fax (360) 586-5366 • e-mail [sbcc@ga.wa.gov](mailto:sbcc@ga.wa.gov) • [www.ga.wa.gov/sbcc](http://www.ga.wa.gov/sbcc)

### **STATE BUILDING CODE INTERPRETATION NO. 17-02**

**CODE:** 2015 Washington State Energy Code - Commercial

**SECTION:** C406, Additional efficiency package options

**QUESTION 1:** Does this provision apply only to new construction.

**ANSWER 1:** **Yes. However, a shell and core project also carries additional requirements for the first tenant build out as indicated in C406.1.1.**

**QUESTION 2:** Does this provision apply to low energy spaces and semi-heated spaces?

**ANSWER:** **Yes, all buildings would need to comply with the options selected. The designer needs to take into consideration that not all options may be applicable and choose accordingly.**

**QUESTION 3:** Does this provision apply to warehouse cooler and freezer spaces?

**ANSWER:** **Yes.**

**SUPERSEDES:** None

**REQUESTED BY:** City of Shoreline