



## **Washington State Building Code Council**

*Improving the built environment by promoting health, safety and welfare*

1500 Jefferson Street SE • P.O. Box 41449 • Olympia, Washington 98504  
(360) 407-9280 • fax (360) 586-5366 • e-mail [sbcc@ga.wa.gov](mailto:sbcc@ga.wa.gov) • [www.ga.wa.gov/sbcc](http://www.ga.wa.gov/sbcc)

### **STATE BUILDING CODE INTERPRETATION NO. 17-04**

- CODE:** 2015 Washington State Energy Code - Commercial
- SECTION:** C406.4, Enhanced digital lighting controls
- QUESTION:** Are the two exceptions addressing track lighting and multiple linear luminaires ganged together, only applicable to control function requirement 2 (*Each luminaire shall be individually addressed*)?
- ANSWER:** **Yes. This is a formatting error within the code. The two exceptions are for item 2 only. Items 3, 4 and 5 are not exceptions, but a continuation of the main list.**
- SUPERSEDES:** None
- REQUESTED BY:** City of Shoreline