



Washington State Building Code Council

Improving the built environment by promoting health, safety and welfare

1500 Jefferson Street SE • P.O. Box 41449 • Olympia, Washington 98504
(360) 407-9280 • fax (360) 586-5366 • e-mail sbcc@ga.wa.gov • www.ga.wa.gov/sbcc

STATE BUILDING CODE INTERPRETATION NO. 17-05

CODE: 2015 Washington State Energy Code - Commercial

SECTION: C406.7, Reduced service water heating

QUESTION: Are Group I-1 licensed care facilities eligible for this option?

ANSWER: **At this time, it is not one of the listed occupancies eligible. The code language would need to be changed to include this type of facility, or specific permission would have to be granted by the local code official based on a Code Alternate per Section C102.1. Group I-1 may be shown to comply with item 7 of C406.7.1.**

SUPERSEDES: None

REQUESTED BY: City of Shoreline