

Group 1 Code Change Proposals - 2018
IFC TAG

*eRule request or off cycle

‡Short Form

Returned for correction

Proponent	Code	Section	Init. Log Number	Log Number	Description	TAG Action	Committee Action	Council Action
Terry Beals, Sound Transit	IBC/IFC	3101/IFC 3801	18-GP1-048	BF01-2018		Proponent is going to re-word a portion of the proposal and re-submit Proposal has been re-worded and Recommended approval Posted 8/27		
					Standard for Fixed Guideway Transit and Passenger Rail Systems			
Jeffrey Hamlett	IBC*/IFC	Mass Timber	18-GP1-050	BF02-2018	Clarify how DOAS and zone terminal units are treated	Not the fire code Defer to the IBC		
Eric Vander Mey	IBC[F]	902.1.1	18-GP1-212	BF03-2018	Fire pump equipment access requirements clarification in NFPA 20.	Recommend Denial		
Eric Vander Mey	IBC [F]	2702.1.5	18-GP1-213	BF04-2018	Run time requirements by NFPA 20 as referenced by the IBC for fire pumps.	Recommend Denial		
Diane Glenn	IFC/IBC	3304.5.1 / 3314.1	18-GP1-080	BF05-2018	Fire watch during nonworking hours for new construction (exceeding 40 feet).	Proposal has been re-worded and Recommended approval Posted 8/27		
Matt Campbell, CRS	IFC	202 Occup Class, LCF	18-GP1-118	F01-2018	Strike "licensed care facility" from state amendment.	Recommend Approval		
Matt Campbell, CRS	IFC	202 RTF	18-GP1-119	F02-2018	Correct amendment from "residential care facility" to I-1, condition 2.	Recommend Approval		
Brian Imai, WSADA	IFC	314	18-GP1-052	F03-2018	Indoor display amendment clarification. Section 314.	Proposal has been re-worded and Recommended approval Posted 8/27		
Traci Harvey	IFC	T 315.7.6(1)	18-GP1-015	F04-2018	Correction to table 315.7.6(1) Wood pallet separation distance from building.	Recommend approval		
Ken Brouillette, Seattle	IFC	510.4	18-GP1-071	F05-2018	Requirements to test and list equipment installed to enhance emergency responder radio coverage in a building.	Recommend approval		
Ken Brouillette, Seattle	IFC	510.4.1.1	18-GP1-072	F06-2018	Proposal intended to put the minimum design criteria of -95dBm back into the code.	Recommend approval		
Ken Brouillette, Seattle	IFC	510.4.2.4	18-GP1-073	F07-2018	Signal booster requirements, If used.	Recommend approval Change IP-66 to IP-65 in the proposal Posted 8/27		
Ken Brouillette, Seattle	IFC	510.4.2.5	18-GP1-074	F08-2018	Add "Oscillation of active RF-emitting devices(s)" to section 510.4.2.5	Recommend approval		
Ken Brouillette, Seattle	IFC	510.5	18-GP1-075	F09-2018	Section correction from 510.5.4 to 510.5.5	Recommend approval		
Ken Brouillette, Seattle	IFC	510.5.3	18-GP1-076	F10-2018	Testing procedures for emergency responder radio coverage.	Recommend approval		
Ken Brouillette, Seattle	IFC	510.5.5 NEW	18-GP1-077	F11-2018	Donor antenna mounting and signage requirements.	Recommend approval		
Ken Brouillette, Seattle	IFC	510.6.1	18-GP1-078	F12-2018	Testing and proof of compliance of emergency responder radio coverage.	Recommend approval		
Ken Brouillette, Seattle	IFC	510.6.1	18-GP1-011	F13-2018	Testing and proof of compliance of emergency responder radio coverage.	Proposal has been re-worded and Recommended approval Posted 8/27		
Mark Murray, UW	IFC	701.6	18-GP1-059	F14-2018	Strike inventory and annual inspection records from Owners Responsibility.	Proposal has been re-worded and Recommended approval Posted 8/27		
Bob Plumb, Chelan	IFC	903.2.8	18-GP1-044	F15-2018	Vacation rental property sprinkler requirement guidance.	Recommend denial of this proposal. It was seconded and unanimous vote. TAG deemed proposal made model code less clear.		
Dave Kokot	IFC	903.2.9	18-GP1-012	F16-2018	Group S-1 self storage automatic sprinkler requirement when fire area exceeds 2500 Square feet.	Recommend approval		
Michael Six	IFC	904.1.1	18-GP1-098	F17-2018	Specific certification(s) requirements when performing life safety work.	Recommended denial. TAG recommends waiting for this to happen at the national level before doing it locally.		
Paul Clark, CRS	IFC	906.2	18-GP1-120	F18-2018	Hoods not required footnote "E" Table 609.2.1	Recommended denial. Proposal will be forwarded to the mechanical TAG. TAG agreed that this should be addressed by the mechanical TAG and not the fire TAG. Group asked that the proponent check the numbering on the proposal, may be some errors.		
Tim Nickols, Electronic Security Assoc.	IFC	907.1	18-GP1-007	F19-2018	Testing, Maintenance and Certification for new and existing fire alarm systems.	Recommend approval-off cycle		
Tim Nickols, ESA	IFC	907.10	18-GP1-043	F20-2018	Certification requirement for fire alarm system testing.	Recommend Denial Conflict with other proposal F-19		
Matt Campbell, CRS	IFC	1010.1.9.3	18-GP1-121	F21-2018	Locks latches and emergency light for Group I-1 Facilities.	Recommend Approval		
Matt Campbell, CRS	IFC	1010.1.9.7	18-GP1-122	F22-2018	Clinical staff shall have means necessary to operate locking systems.	Recommend Approval		
Corey Thomas, Renton	IFC	3803.3.2	18-GP1-045	F23-2018	Areas dedicated to extraction shall be equipped with panic hardware or fire exit hardware.	Recommend Approval		
Traci Harvey	IFC	3904, Ch 80	18-GP1-060	F24-2018	Systems or equipment used for the extraction of oils requirements.	Recommend Approval		
Jacob Blanchette	IFC	5003.11.1 Table	18-GP1-081	F25-2018	Maximum allowable quantity of consumer products Table 5003.11.1 Footnote K.	Recommend Approval		
Ken Brouillette, Seattle	IFC	Ch 80	18-GP1-079	F26-2018	Test and list equipment installed to enhance emergency responder radio coverage in buildings.	Recommend Approval		
Corey Thomas, Renton	IFC	319.1		F27-2018	Mobile food preparations vehicles, Definitions, General	Recommend Approval		