

From: Chappell, Micah <Micah.Chappell@seattle.gov>
Sent: Thursday, September 26, 2019 2:04 PM
Subject: Public Comment

All,
Here is another public comment that I will be making, but not providing a fancy breakdown for either. This exception should be specific to an existing townhouse unit (singular), as written, it could be interpreted that one would have to alter multiple units for the exception to apply.

WAC 51-51-0313 Section R313—Automatic fire sprinkler systems.
((This section is not adopted.)) R313.1 Townhouse automatic fire sprinkler systems. An automatic residential fire sprinkler system shall be installed in townhouse units.

EXCEPTIONS:

1. An automatic residential fire sprinkler system shall not be required where additions or alterations are made to **an** existing townhouse **units** that **does** not have an automatic residential fire sprinkler system installed.
2. Townhouse buildings containing no more than four townhouse units.

Thank you,



Micah Chappell, MBA, CBO
Technical Code Development Manager

Seattle [Department of Construction and Inspections](#)

P.O. Box 34019, Seattle, WA 98124-4019

P: 206.256.5157 | F: 206.386.4039 | micah.chappell@seattle.gov



Helping people build a safe, livable, and inclusive Seattle.



Micah Chappell, MBA, CBO
Executive Board
Technical Code Committee Chair

P: 206.256.5157 | F: 206.386.4039 | micah.chappell@seattle.gov