

**From:** Curtright, Michael <Michael.Curtright@macmiller.com>

**Sent:** Sunday, September 15, 2019 5:36 PM

**To:** DES SBCC <sbcc@des.wa.gov>

**Subject:** Testimony on the adoption of the 2018 UPC

Code verbiage needing clarification:

407.2 – indicates max. for “kitchen sinks” as 2.5 GPM

Whereas 420.2 indicates max. for “sink faucets” as 2.2 GPM



**Michael Curtright**  
Design Engineer

D: 206-768-4146

24 Hour Service | 1-855-MAC-HVAC

7717 Detroit Ave SW, Seattle, WA 98106

