

From: Eric Vander Mey <ericv@rushingco.com>
Sent: Friday, September 27, 2019 10:01 AM
To: DES SBCC <sbcc@des.wa.gov>
Subject: RE: Public Comment - 2018 IMC Washington Amendments

See correction below to one of the table reference numbers for Table 403.8.7...

Comment IMC Table 403.3:

Tag modified table to refer to local exhaust tables. Changes were not picked up in CR-102.

Recommended Changes in Red:

| Occupancy | Occupant Density #/1000 ft ^{2a} | People Outdoor Airflow Rate in Breathing Zone R _p cfm/Person | Area Outdoor Airflow Rate in Breathing Zone R _a cfm/ft ^{2a} | Exhaust cfm/ft ^{2a} |
|--|--|--|---|---|
| Classification Private | | | | |
| dwelling, single and multiple | — | — | — | 0.75 |
| Garages, common for multiple | — | — | — | 25/100 ^f See Table |
| units ^b ((Kitchens ^b | Based on the number of bedrooms. First bedroom, 2; each additional bedroom, 1 | See Tables 403.8.1 and 403.8.5.1 | — | 403.8.7 |
| Living areas ^c | | See Table 403.8.2 | — | — |
| Toilet rooms, bathrooms and laundry areas ^{g, 1} | — | — | — | 20/50 ^f) See Table 403.8.7 |

Eric Vander Mey - PE, LEED®AP

Principal – Director of Engineering

RUSHING | D 206-285-7114 | C 206-321-1677

www.rushingco.com