

DRAFT STATE BUILDING CODE OPINION 20-Nov03

CODE: 2018 International Mechanical Code

SECTION: Table 403.3.1.1

QUESTION: It appears that portions of Table 403.3.1.1 were omitted in the 2018 adoption of the International Mechanical Code. Did the Council intend to remove the occupancy classifications not included in the state amendment?

ANSWER: **No. The occupancies shown in the state amendment are those that were modified. The occupancies not reflected in the state amendment were unchanged and are intended to be included in the state adoption of the 2018 International Mechanical Code.**

SUPERSEDES: None

REQUESTED BY: City of Bellevue