

Fire Department Permit Conditions



Site Address: _____

Inspector: _____

On-Demand Mobile Fueling Site


This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. [WA State Fire Code Section 105.3.5]

1. An operational permit is required to utilize a site for On-Demand Mobile Fueling operations. [WA State Fire Code Section 105.6.16 #11]
2. The approval of the owner of the site shall be obtained to conduct On-Demand Mobile Fueling and documentation shall be provided to the fire code official. [WA State Fire Code Section 105.1.1]
3. A site plan shall be developed for each location at which mobile fueling occurs. The site plan shall be in sufficient detail to indicate: all buildings, structures, lot lines, property lines, electric car chargers, solar photovoltaic parking lot canopies, and appurtenances on site and their use or function; all uses adjacent to the lot lines of the site; fueling locations, the locations of all storm drain openings and adjacent waterways or wetlands; information regarding slope, natural drainage, curbing, impounding and how a spill will be kept on the site property; and the scale of the site plan. [WA State Fire Code Section 5707.3.3]
4. Engaging in the dispensing of fuel into vehicles at this location shall only be conducted by an On-Demand mobile fueling company who has a valid On-Demand mobile fueling operational permit issued by the fire code official. [WA State Fire Code Section 105.6.16 #10]
5. Mobile Fueling on an approved site shall only be from fueling vehicles approved by the fire code official. Each fueling vehicle shall have a separate permit. [WA State Fire Code Section 105.6.16 #6 and 105.7.9]
6. The mobile fueling operation and the point of connection of the vehicle being fueled shall not occur on public streets, public ways or inside buildings. Mobile Fueling on the roof level of parking structures or other buildings is prohibited. [WA State Fire Code Section 5707.4]
7. Mobile fueling shall not take place within 25 feet (7620 mm) of buildings, lot lines, property lines or combustible storage.

Exception:

The fire code official shall be authorized to decrease the separation distance for dispensing from metal safety cans or other approved metal containers.
[WA State Fire Code Section 5707.4.1]

Fire Department Permit Conditions



Site Address: _____

Inspector: _____

On-Demand Mobile Fueling Site

8. Smoking, open flames and other sources of ignition shall be prohibited within 25 feet (7620 mm) of fuel dispensing activities. Signs prohibiting smoking or open flames within 25 feet (7620 mm) of the vehicle or the point of fueling shall be prominently posted on the mobile fueling vehicle. The engines of vehicles being fueled shall be shut off during fueling. [WA State Fire Code Section 5707.4.2]