


Note: This is a Sample Document and has not been updated with proposed new WA State Fire Code Language

Fire Department Permit Conditions



Site Address: _____

Inspector: _____

On-Demand Mobile Fueling Operator

This permit shall be kept on the premises designated herein at all times and shall be readily available for inspection by the fire code official. [WA State Fire Code Section 105.3.5]

1. On-Demand Mobile Fueling shall only be from fueling vehicles approved by the Fire Code Official. Each fueling vehicle shall have a separate permit. [WA State Fire Code Section 105.6.16 #6 and 105.7.9]
2. On-Demand Mobile Fueling shall only be conducted at sites that have an operational permit issued by the Fire Code Official. [WA State Fire Code Section 105.6.16 #11]
3. On-Demand Mobile Fueling shall not occur on public streets, public ways, inside of buildings or on the roof or inside of any parking structure. [WA State Fire Code Section 5707.4]
4. Mobile fueling operators shall have an *approved* written safety and emergency response plan that establishes policies and procedures for fire safety, spill prevention and control, personnel training and compliance with other applicable requirements of this code. [WA State Fire Code Section 5707.3.1]
5. Mobile fueling vehicles shall be operated only by designated personnel who are trained on proper fueling procedures and the safety and emergency response plan. Training records of operators shall be maintained. [WA State Fire Code Section 5707.3.2]
6. Mobile fueling vehicles shall be constantly attended during fueling operations with brakes set and warning lights in operation. Mobile fueling vehicles shall not obstruct emergency vehicle access roads. [WA State Fire Code Section 5707.6]

Permits can be revoked after they are issued. To verify that a permit is current and in good standing call [issuing jurisdiction] or email [issuing jurisdiction]. Information also available at [issuing jurisdiction website], although that information may not be updated daily.

On-Demand Mobile Fueling Operator

Site Address: _____

Inspector: _____

7. Mobile fueling vehicles shall be positioned in a manner to preclude traffic from driving over the dispensing hose. The dispensing hose shall be properly placed on an approved reel or in an approved compartment prior to moving the mobile fueling vehicle. [WA State Fire Code Section 5707.6.1]
8. Operators shall place a drip pan or an absorbent pillow under the nozzle and each fuel fill opening prior to and during dispensing operations to catch drips. [WA State Fire Code Section 5707.6.2]
9. Safety cones or other visual barriers shall be employed as warning devices to highlight the vehicle fueling area. [WA State Fire Code Section 5707.6.3]
10. The mobile fueling vehicle flasher lights shall be in operation while dispensing operations are in progress. [WA State Fire Code Section 5707.6.4]
11. The mobile fueling vehicle and its equipment shall be maintained in good repair. [WA State Fire Code Section 5707.2.2(2)]
12. Safety cans and approved metal containers shall be secured to the mobile fueling vehicle except when in use. [WA State Fire Code Section 5707.2.2(3)]
13. Fueling a motor vehicle from tanks or containers mounted in a trailer connected to a mobile fueling vehicle is prohibited. [WA State Fire Code Section 5707.2.2 (4)]