

## STATE BUILDING CODE OPINION 21-Feb01

**CODE:** 2018 Washington State Energy Code-Residential

**SECTION:** R405, Simulated Performance Alternative

**QUESTION:** Would the use of Section R405 to show compliance still require the additional energy credits from Section R406?

**ANSWER:** **Yes. Projects showing compliance with the energy code via the performance method would still need to comply with the appropriate number of credits in Section R406.3.**

**SUPERSEDES:** None

**REQUESTED BY:** Spokane County