

# Washington State Building Code Council • Code Change Cycle 2021 Group 1

## 2021 International Building Code Review Worksheet

2021 Code Section	2018 Code Section	Title or Subject	Reviewer Comments	Costs (Y/N)	Amend Needed (Y/N)	TAG Comments/ Recommendation
<b>Chapter 8 Interior Finishes</b>						
806.9 New Section	N/A	Combustible lockers	The regulation of combustible lockers, previously limited to Section 808.4 of the IFC, is now also addressed in the IBC. This allows for regulation before and during construction rather than only after occupancy during a fire service inspection.	N	N	
<b>Chapter 26 Plastic</b>						
2602.1	2602.1	Exterior wall covering and architectural trim	The title (Exterior finish and trim) is modified to read "Exterior wall covering and architectural trim." The text is also modified to align with the title.	N	N	
2603.1.1 New Section	N/A	Spray-applied foam plastic	New section specifies single- and multiple-component spray-applied foam plastic insulation shall comply with the provisions of Section 2603 and ICC 1100-2018.	N	N	
2606.7.4	2606.7.4	Automatic sprinkler system	The title (Fire suppression system) is modified to read "Automatic sprinkler system." The current requirement for buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 mandates plastic light-diffusing systems to be protected both above and below <u>unless</u> the sprinkler system has been specifically approved for installation only above the light-diffusing system. The modified section provides another option for compliance – if the light-diffusing system is listed and labeled in accordance with UL 723S.	N	N	

2021 Code Section	2018 Code Section	Title or Subject	Reviewer Comments	Costs (Y/N)	Amend Needed (Y/N)	TAG Comments/ Recommendation
2607.5	2607.5	Automatic sprinkler system (for light-transmitting plastic wall panels)	The current language provides requirements for buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 pertaining to maximum percentage area increase of exterior wall in any story in light-transmitting plastic wall panels and the maximum square footage of a single area given in Table 2607.4, and specifies that such installations are exempt from height limitations. The modified section limits these installations to 75 feet above grade plane.	Uncertain	N	
2610.1 2610.1.1	2610.1	Light-transmitting plastic glazing of skylight assemblies.	Reformatting; relocates the requirements for unit skylights, currently in Section 2610.1, to new Section 2610.1.1.	N	N	