



Washington State Building Code Council

Improving the built environment by promoting health, safety and welfare

1500 Jefferson Street SE • P.O. Box 41449 • Olympia, Washington 98504
(360) 407-9277 • e-mail sbcc@des.wa.gov • www.sbcc.wa.gov

STATE BUILDING CODE OPINION NO. 21-01

CODE: 2018 Washington State Energy Code - Residential

SECTION: C405, Simulated Performance Alternative

QUESTION: Would the use of Section R405 to show compliance still require the additional energy credits from Section R406?

ANSWER: **Yes. Projects showing compliance with the energy code via the performance method would still need to comply with the appropriate number of credits in Section R406.3.**

SUPERSEDES: None

REQUESTED BY: Spokane County