



STATE OF WASHINGTON
STATE BUILDING CODE COUNCIL

May 2018
Log No. _____

1. State Building Code to be Amended:

- | | |
|---|---|
| <input checked="" type="checkbox"/> International Building Code | <input type="checkbox"/> International Mechanical Code |
| <input type="checkbox"/> ICC ANSI A117.1 Accessibility Code | <input type="checkbox"/> International Fuel Gas Code |
| <input type="checkbox"/> International Existing Building Code | <input type="checkbox"/> NFPA 54 National Fuel Gas Code |
| <input type="checkbox"/> International Residential Code | <input type="checkbox"/> NFPA 58 Liquefied Petroleum Gas Code |
| <input checked="" type="checkbox"/> International Fire Code | <input type="checkbox"/> Wildland Urban Interface Code |
| <input type="checkbox"/> Uniform Plumbing Code | |

For the Washington State Energy Code, please see specialized [energy code forms](#)

Section(s): 2021 IFC Sections 508.1.2 and 2021 IBC Section 911.1.2

Title: Separation

2. Proponent Name (Specific local government, organization or individual):

Proponent: Ken Brouillette (Seattle Fire Department)

Title: Technical Code Program Manager

Date: 2/23/2021

3. Designated Contact Person:

Name: Ken Brouillette (Seattle Fire Department)

Title: Technical Code Program Manager

Address: 220 3rd Ave. S, Seattle, WA 98104

Office Phone: (206)386-1455

Cell: ()

E-Mail address: ken.brouillette@seattle.gov

4. Proposed Code Amendment. Reproduce the section to be amended by underlining all added language, striking through all deleted language. Insert new sections in the appropriate place in the code in order to continue the established numbering system of the code. If more than one section is proposed for amendment or more than one page is needed for reproducing the affected section of the code additional pages may be attached. (Examples on the SBCC [website](#))

Code(s) 2021 IFC and 2021 IBC Section(s) 508.1.2 and 911.1.2

Enforceable code language must be used; see an example [by clicking here](#).
Amend sections to read as follows:

508.1.2 Separation. The *fire command center* shall be separated from the remainder of the building by not less than a + 2-hour *fire barrier* constructed in accordance with Section 707 of the *International Building Code* or *horizontal assembly* constructed in accordance with Section 711 of the *International Building Code*, or both.

911.1.2 Separation. The *fire command center* shall be separated from the remainder of the building by not less than a + 2-hour *fire barrier* constructed in accordance with Section 707 ~~of the *International Building Code*~~ or *horizontal assembly* constructed in accordance with Section 711 ~~of the *International Building Code*~~, or both.

5. Briefly explain your proposed amendment, including the purpose, benefits and problems addressed.
This proposal is to maintain the existing State amendment in the fire code and show it as an amendment in the building code.

6. Specify what criteria this proposal meets. You may select more than one.

- The amendment is needed to address a critical life/safety need.
- The amendment clarifies the intent or application of the code.
- The amendment is needed to address a specific state policy or statute.
- The amendment is needed for consistency with state or federal regulations.
- The amendment is needed to address a unique character of the state.
- The amendment corrects errors and omissions.

7. Is there an economic impact: Yes No

Explain:

If there is an economic impact, use the tool below to estimate the costs and savings of the proposal on construction practices, users and/or the public, the enforcement community, and operation and maintenance. If preferred, you may submit an alternate cost benefit analysis.

Provide your best estimate of the construction cost (or cost savings) of your code change proposal? (See OFM Life Cycle Cost [Analysis tool](#) and [Instructions](#); use these [Inputs](#). [Webinars on the tool can be found Here and Here](#))

\$Click here to enter text./square foot (For residential projects, also provide \$Click here to enter text./dwelling unit)

Show calculations here, and list sources for costs/savings, or attach backup data pages

List any code enforcement time for additional plan review or inspections that your proposal will require, in hours per permit application:

Please send your completed proposal to: sbcc@des.wa.gov

All questions must be answered to be considered complete. Incomplete proposals will not be accepted.