

2021 Code Section	2018 Code Section	Title or Subject	Reviewer Comments	Sig. Change (Y/N)	Costs (Y/N)	WA Amend Needed (Y/N)	TAG Comments/ Recommendations to MVE Committee
2021 INTERNATIONAL RESIDENTIAL CODE, Chapters 12 - 24							
Chapter 15 Exhaust Systems							
TAG Member Assigned: Nancy, Mike and Tom							
M1502.3	M1502.3	Duct Termination	Accept new language	N	N	N	
M1502.4.5		Booster Fans Prohibited	Accept new language	N	N	N	
			Accept renumbering	N	N	N	
M1503.2.1	M1503.2.1	Open-top broiler exhaust	Existing State Amendment Adds an exception allowing outdoor broiler units without hoods Staff Recommendation: Retain state amendment				Concur with Staff
M1504.3	M1504.3	Exhaust openings	Existing State Amendment Adds an allowance for H/ERV installed per MII Staff Recommendation: Retain state amendment				Concur with Staff Subject does not seem accurate? ((Item 3.2))
M1505.1	M1505.1	General	Modify amendment to add new language	N	N	N	
M1505.3	M1505.3	Exhaust equipment	Modify amendment to add new language	N	N	N	
M1505.4 (and all subsections)	Same	Mechanical ventilation	Existing State Amendment State whole house ventilation requirements Staff Recommendation: Retain state amendment				Retain and add new language to 1505.1, 1505.3, 1505.4.2, 1505.4.3, footnote a to Table 1505.4.4(1). Add a new exception to M1505.4 to allow the use of ASHRAE 62.2 – 2019
M1505.4.2	M1505.4.2	System controls	Modify amendment to add new language	N	N	N	
M1505.4.3	M1505.4.3	Mechanical ventilation rate	Modify amendment to add new language	N	N	N	Need to discuss Exceptions

