

From: Randall King <rking@kitsapbuilds.com>

Sent: Wednesday, February 9, 2022 2:27 PM

To: DES SBCC <sbcc@des.wa.gov>

Subject: RE: International Fire Code & International Building Code; Section 903.3.1.2 (21-GP1-020) – Sprinkler Systems in Low-Rise Residential Buildings

Kitsap Building Association supports Section 903.3.1.2. in an effort to preserve affordability of residential buildings by ensuring applicability of NFPA 13R systems are preserved. Lower density multi-family buildings otherwise would have been subjected to a full NFPA 13 system which would drastically increase the cost of construction. We commend this effort to keep housing affordability at the forefront of the code development conversation.

Best regards,
Randall

Randall M. King
Executive Officer
Kitsap Building Association
5251 Auto Center Way
Bremerton, Washington 98312
360.479.4210 direct
www.kitsapbuilds.com

