

# Washington State Commercial Building Energy Modeling Analysis

Prepared for the Washington State Energy Code Technical Advisory Group (TAG)

**Prepared on behalf of:**

California Statewide Utility Codes and Standards Team

**Prepared by:**

Neil Bulger, A2 Efficiency  
Shilpa Surana, Kristen Driskell, 2050 Partners  
August 28, 2023

This report was prepared on behalf of the California Statewide Codes and Standards Program that is funded, in part, by California utility customers under the auspices of the California Public Utilities Commission.

Copyright 2023 Pacific Gas and Electric Company. All rights reserved, except that this document may be used, copied, and distributed without modification.

Neither Pacific Gas and Electric Company or any of its employees makes any warranty, express or implied; or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any data, information, method, product, policy, or process disclosed in this document; or represents that its use will not infringe any privately-owned rights including, but not limited to, patents, trademark or copyrights.

# WA EPCA Commercial Building Energy Modeling Analysis

Date: 08/28/2023

## Executive Summary of Energy Analysis

### Overview

The 2021 Washington State Energy Code – Commercial (WSEC-C) is currently under review and revision to explore the integration of gas-based systems in buildings while maintaining the required level of efficiency standards. The Energy Code Technical Advisory Group has sought support from the California Investor-Owned Utilities (CA IOUs) Code and Standards team to evaluate a series of building energy models to aid in the development of a set of energy efficiency credits based on a proposed enhancement to the prescriptive code. The CA IOUs have been advocates for multiple improvements to both the International Energy Conservation Code (IECC) and the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) standard 90.1. These efforts aim to enhance national energy efficiency and contribute to potential advancements in California's future building standards. While this collaboration is focused on aiding the Washington state energy code, many elements within the proposal offer possibilities for similar applications in the IECC, ASHRAE 90.1, and future California state building code and reach code advancements.

The following memo outlines the approach and assumptions used in the development of typical building energy modeling results for the 2021 Washington State Energy Code – Commercial (WSEC-C) Energy Policy Conservation Act (EPCA) compliant prescriptive pathway for a natural gas and all electric system. Modeling assumptions<sup>1</sup> utilized in developing a series of energy models and the results of the simulation in two climate zones in Washington State are included below.

### Energy Modeling Framework

Energy modeling of prototypical buildings were used to evaluate the energy use with two different fuel options for space heating and water heating, one based on all electric sources and one based on natural gas sources. Models were developed from a set of pre-existing EnergyPlus models developed for 2018 WSEC-C code evaluations. Models were modified to generate the different heating components necessary to create the different fuel options. Due to time constraints in analysis, no additional efficiency modifications were made to these prototype models to represent the 2021 code provisions. The models are detailed enough to establish the difference in site energy use across major building types between natural gas heating technologies and electric heat pump equipment. The modeled results and additional efficiency credits developed in this analysis only represent the starting point for a code change proposal which was developed outside of this report and includes several modifications when utilizing these results.

Models were evaluated in two ASHRAE Climate Zones, 4C and 5B in Washington State utilizing Seattle and Spokane weather files. Six building prototypes were developed to determine site energy use and efficiency credit differences.

---

<sup>1</sup> Detailed modeling assumptions and link to modeling files are available upon request.

## Additional Energy Credits

Credits are based on site energy difference from a gas-based system to an all-electric system for space and domestic hot water heating. These credits would be included in the 2021 code language revisions proposed for WSEC-C<sup>2</sup>. Based on the models available, the final construction group 'All Other' was estimated based on averaging all other building types as a reasonable estimate of efficiency differences.

Model Mapping to Construction Group	<i>Hotel Small</i>	<i>MF Apartment Midrise</i>	<i>Office Medium</i>	<i>School Primary</i>	<i>Retail Stand Alone</i>	<i>Avg</i>
-------------------------------------	--------------------	-----------------------------	----------------------	-----------------------	---------------------------	------------

Additional Credits	Group R-1	Group R-2	Group B	Group E	Group M	All Other
Space Heating	7	24	101	38	111	56
Domestic Hot Water	198	204	27	17	79	105
<b>Total</b>	<b>205</b>	<b>228</b>	<b>128</b>	<b>55</b>	<b>190</b>	<b>161</b>

Construction weighted to be 75% in CZ4C, 25% in CZ5B

Space Heating Credits			
Building Prototype	CZ4C	CZ5B	Weighted Average (Rounded)
Office Medium	93	126	101
MF Apartment Midrise	17	45	24
School Primary	33	54	38
Warehouse	134	200	151
Retail Stand Alone	98	149	111
Hotel Small	6	11	7

Domestic HW Credits			
Building Prototype	CZ4C	CZ5B	Weighted Average (Rounded)
Office Medium	28	25	27
MF Apartment Midrise	219	159	204
School Primary	20	10	17
Warehouse	28	17	26
Retail Stand Alone	83	66	79
Hotel Small	196	202	198

<sup>2</sup> [https://sbcc.wa.gov/sites/default/files/2023-05/2021\\_WSEC\\_C\\_2ndPrint\\_0518023.pdf](https://sbcc.wa.gov/sites/default/files/2023-05/2021_WSEC_C_2ndPrint_0518023.pdf)

# Energy Analysis in Support of WA Compliance Pathway Development

8/28/2023  
A2 Efficiency

The following energy analysis was developed for support of multiple heating fuel pathways for the WA 2021 code. The project was in support of identifying opportunities for further enhancements to energy codes both federal and state in other jurisdictions where similar challenges to advancing cost effective, low emission systems will be needed.

## Contents

Executive Summary of Energy Analysis .....	2
Overview .....	2
Energy Modeling Framework .....	2
Additional Energy Credits .....	3
Energy Modeling Inputs .....	5
Systems Map for Space Heating and Domestic Hot Water Systems .....	5
Domestic Hot Water System Efficiency Assumptions .....	6
Model Enhancements for Indirect Assumptions .....	8
Appendix 1: Energy Modeling Results .....	9
Office Medium .....	9
Apartment-Midrise .....	10
School-Primary .....	11
Retail Stand Alone .....	12
Warehouse .....	13
Hotel Small .....	14
Appendix 2: Energy Modeling Key Inputs for Efficiency .....	15

## Energy Modeling Inputs

### Systems Map for Space Heating and Domestic Hot Water Systems

The following systems were utilized in each prototype for space heating and water heating in the following all electric and gas system models:

Building Prototype	Electric Systems		Gas Systems	
	Space Heating	DHW Heating	Space Heating	DHW Heating
Office Medium	DOAS + Fan Coil Air to Water Heat Pump	HPWH central*	DOAS + Fan Coil Boiler central	Gas WH central
Apartment Midrise	DOAS + Unitary HP, Split System	HPWH central*	DOAS + Unitary AC with Furnace	Gas WH unitized
School Primary	DOAS + Unitary HP, Single Packaged	HPWH central*	DOAS + Unitary AC with Furnace	Gas WH unitized
Warehouse	DOAS + Unitary HP, Single Packaged	HPWH unitary*	DOAS + Unitary AC with Furnace	Gas WH unitary
Retail Stand Alone	DOAS + Unitary HP, Single Packaged	HPWH unitary *	DOAS + Unitary AC with Furnace	Gas WH unitary
Hotel Small	DOAS + Unitary HP Split System in common PTAC AC-Elec guest rooms	HPWH central*	DOAS + Unitary AC with Furnace in common PTAC AC-Elec guest rooms	Gas WH central

*\*all HPWH system included an electric resistance element located in a swing tank for central systems and in the primary tank for unitary systems for peak demand instances.*

## Domestic Hot Water System Efficiency Assumptions

Efficiency values for each heat pump unit were derived from minimum efficiency criteria tables as outlined in Section C403 of the 2021 WSEC-Commercial provisions. For all heat pump models, the heat pumps were configured along with a heating element in the secondary swing tank to provide heat. For centralized systems, electric resistance was included in the secondary swing-tank, which provided heating for the recirculation loop and pipe losses in the buildings.

Heat Pump Water Heater (HPWH) efficiency was determined to be two different values:

DHW System	Efficiency
HPWH unitized (stand alone without a pump)	UEF $\geq$ 2.24 (WA 2021) COP = 2.24 (assumed)
HPWH central	COP 2.31 for CZ4c COP 1.63 for CZ5b

1. COP 2.31 Table 403.3.2(15) Heat Pump and Heat Recovery Chiller Minimum Efficiency; Air Source, 47F, 140F Supply Water
2. COP 1.63 Table 403.3.2(15) Heat Pump and Heat Recovery Chiller Minimum Efficiency; Air Source, 17F, 140F Supply Water
3. For smaller systems (such as unitary), Table C404.2 requires at the most a UEF of  $\geq$  2.24.

Key information on sizing of each system in each building prototype is included in the following table. Pipe losses for each HPWH system are accounted for as “Parasitic losses”, shown for the swing tank object, with the same value for On and Off in the simulated model as shown in the table below.

The following are key assumptions for sizing each heat pump water heater in the all electric systems. In EnergyPlus, heat pump water heaters are defined by multiple objects with several parameters requiring manual sizing.

EnergyPlus Object	Attribute	Unit	Medium Office	Hotel, DHW	Hotel, Laundry	Apartment, Midrise	Retail Standalone	School, Primary	Warehouse
HPWH Sched	Supply	F	139.1	139.1	139.1	139.1	139.1	139.1	139.1
WaterHeater:Stratified	Tanks Size	gal	465	465	465	465	40	250	20
	Heat Capacity 1	Watts	2,951	9,901	7,116	6,243	1,040	5,800	443
	Off Cycle Parasitic	Watts	472	1584	1139	999	166	928	71
	On Cycle Parasitic	Watts	472	1584	1139	999	166	928	71
Coil:WaterHeating:Air ToWater HeatPump:Pumped	Heating Capacity	Btu/h	20,135	67,564	48,559	42,600	7,096	39,579	3,026
DHW Temperature Change		Delta-F	86.1	86.1	86.1	86.1	86.9	86.9	86.9
Peak Heating Load	=500*gpm*delta-t	Btu/h	20,135	67,564	48,559	42,600	7,096	39,579	3,026
	Sizing Factor	%	1.4	1.4	1.4	1.4	1.4	1.4	1.4
		Btu/h	28,188.8	94,590.0	67,982.2	59,640.1	9,934.8	55,410.7	4,236.7
	Heating Capacity	Watts	5,311	17,822	12,809	11,237	1,872	10,440	798
	Efficiency (CZ4c)1	COP <sub>47</sub>	2.31	2.31	2.31	2.31	n/a	2.31	n/a
	Efficiency (CZ5b)2	COP <sub>17</sub>	1.63	1.63	1.63	1.63	n/a	1.63	n/a
	Efficiency (Unitary)3	UEF	n/a	n/a	n/a	n/a	2.24	n/a	2.24
	Pump Power	Btu/h	512	512	512	512	0	512	0
Circulation Pump	Included	Y/N	yes	yes	yes	yes	no	yes	no
Fan:SystemModel	Pressure	inH2O	0.401	0.401	0.401	0.401	0.401	0.401	0.401
WaterUse:Equipment	Peak Flow rate	gal/min	0.06	3.70E-02					
Number of Water Uses	#		15.00	77					
Total Flow Peak	Peak Flow rate	gal/min	0.85	2.85	2.05	1.80	0.30	1.67	0.13
<b>Calculated Parameters</b>									
HP Power	Compressor	Watts	2,555	8,572	6,161	5,405	928	5,022	396
Ratio Swing Tank Elec Total		%	54%	54%	54%	54%	53%	54%	53%
Capacity of HP to Load Peak		%	100%	100%	100%	100%	100%	100%	100%
Parasitic Load to Capacity		%	16%	16%	16%	16%	16%	16%	16%
Tank Size to Flow	size/flow	hrs	9.12	2.72	3.78	4.31	2.23	2.49	2.61

1. Table 403.3.2(15) Heat Pump and Heat Recovery Chiller Minimum Efficiency; Air Source, 47F, 140F Supply Water
2. Table 403.3.2(15) Heat Pump and Heat Recovery Chiller Minimum Efficiency; Air Source, 17F, 140F Supply Water

## Model Enhancements for Indirect Assumptions

For select models, the assumptions to building usage was enhanced to better represent anticipated building use patterns which directly impact building heating and hot water use. Values were modified based on identified sources of information and informed by evaluating the resultant end use for space heating and domestic hot water compared with measured building data showing end uses.

*By Building, note each building and if no changes, note (same as DOE / PNNL assumptions from 2018 WA code evaluation).*

### **Office Medium**

HVAC system changed from WSHP to be Four-Pipe-Fan-Coils with either AWHP or Boiler so the natural gas systems is 100% gas or 100% electric. WSHP with boiler represents a hybrid system with higher efficiencies.

- Office envelope assumptions were also updated in all models to better represent heating loads.
  - Changes in air leakage coefficients for wind speed, temperature
  - Changes to window U-factors to account for thermal bridging of frames
- Office internal gains were modified to better represent lower internal gains requiring more heating:
  - Reduced elevator power
  - Reduced equipment in office power density
  - Reduced occupancy schedule value peaks
  - Reduced lighting schedule value peaks
- Office domestic hot water flow rate at peak was reduced to better match expected office heating EUI. Target EUI for office water use based on CA Title 24 flow rates and schedules.

### **School Primary**

No changes

### **Apartment Midrise**

No changes

### **Warehouse**

No changes

### **Retail**

No changes

### **Hotel**

No changes



# Appendix 1: Energy Modeling Results

## Office Medium

		office-medium				office-medium			
		CZ4C	CZ4C			CZ5B	CZ5B		
		gas	hp	Site Savings (%)	Site Savings EUI	gas	hp	Site Savings (%)	Site Savings EUI
Equipment Int.	<i>kBtu/sf</i>	13.3	13.3	0%	0.0	13.3	13.3	0%	0.0
Equipment Ext.	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Equipment Refrig.	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Lighting Int.	<i>kBtu/sf</i>	3.0	3.0	0%	0.0	3.0	3.0	0%	0.0
Lighting Ext.	<i>kBtu/sf</i>	1.2	1.2	0%	0.0	1.2	1.2	0%	0.0
Fans	<i>kBtu/sf</i>	1.6	1.5	8%	-0.1	2.0	1.6	17%	-0.3
Pumps	<i>kBtu/sf</i>	0.4	0.4	-14%	0.1	0.43	0.52	-21%	0.1
Cooling	<i>kBtu/sf</i>	6.2	6.1	1%	-0.1	6.4	6.4	1%	0.0
Space Heat, Gas	<i>kBtu/sf</i>	4.3	0.0	100%	-4.3	8.9	0.0	100%	-8.9
Space Heat, Elec	<i>kBtu/sf</i>	0.0	1.4	0%	1.4	0.0	4.3	0%	4.3
DHW, Gas	<i>kBtu/sf</i>	1.2	0.0	100%	-1.2	1.2	0.0	100%	-1.2
DHW, Elec	<i>kBtu/sf</i>	0.0	0.5	0%	0.5	0.0	0.6	0%	0.6
BACK CHECK EUI		31.1	27.4	12%	-3.8	36.4	30.9	15%	-5.5
<b>TOTAL</b>	<b><i>kBtu/sf</i></b>	<b>31.1</b>	<b>27.4</b>	<b>12%</b>	<b>-3.8</b>	<b>36.4</b>	<b>30.9</b>	<b>15%</b>	<b>-5.5</b>
		Site Energy: Gas	Site Energy: Elec	Energy Savings (% site)	Additional Credits	Site Energy: Gas	Site Energy: Elec	Energy Savings (% site)	Additional Credits
Equipment	<i>kBtu/sf</i>	13.3	13.3			13.3	13.3		
Lighting	<i>kBtu/sf</i>	4.2	4.2			4.2	4.2		
Space Heating	<i>kBtu/sf</i>	4.3	1.4	9.3%	93	8.9	4.3	12.6%	126
DHW (+ HVAC)	<i>kBtu/sf</i>	9.4	8.5	2.8%	28	10.0	9.1	2.5%	25
		31.12	27.36			36.38	30.85		
			12.1%				15.2%		

## Apartment-Midrise

		multifamily-midrise				multifamily-midrise			
		CZ4C	CZ4C			CZ5B	CZ5B		
		gas	hp	Site Savings (%)	Site Savings EUI	gas	hp	Site Savings (%)	Site Savings EUI
Equipment Int.	<i>kBtu/sf</i>	13.5	13.5	0%	0.0	13.5	13.5	0%	0.0
Equipment Ext.	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Equipment Refrig.	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Lighting Int.	<i>kBtu/sf</i>	3.6	3.6	0%	0.0	3.6	3.6	0%	0.0
Lighting Ext.	<i>kBtu/sf</i>	0.7	0.7	0%	0.0	0.7	0.7	0%	0.0
Fans	<i>kBtu/sf</i>	2.2	2.2	-1%	0.0	2.4	2.8	-13%	0.3
Pumps*	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Cooling	<i>kBtu/sf</i>	2.5	2.2	13%	-0.3	2.8	2.5	10%	-0.3
Space Heat, Gas	<i>kBtu/sf</i>	1.3	0.0	100%	-1.3	4.3	0.0	100%	-4.3
Space Heat, Elec	<i>kBtu/sf</i>	0.0	0.6	0%	0.6	0.0	2.3	0%	2.3
DHW, Gas	<i>kBtu/sf</i>	15.8	0.0	100%	-15.8	15.8	0.0	100%	-15.8
DHW, Elec	<i>kBtu/sf</i>	0.0	7.4	0%	7.4	0.0	8.9	0%	8.9
BACK CHECK EUI		39.6	30.3	24%	-9.3	43.1	34.3	20%	-8.8
<b>TOTAL</b>	<b><i>kBtu/sf</i></b>	<b>39.6</b>	<b>30.2</b>	<b>24%</b>	<b>-9.3</b>	<b>43.1</b>	<b>34.3</b>	<b>20%</b>	<b>-8.8</b>
		Site Energy: Gas	Site Energy: Elec	Energy Savings (% site)	Additional Credits	Site Energy: Gas	Site Energy: Elec	Energy Savings (% site)	Additional Credits
Equipment	<i>kBtu/sf</i>	13.5	13.5			13.5	13.5		
Lighting	<i>kBtu/sf</i>	4.3	4.3			4.3	4.3		
Space Heating	<i>kBtu/sf</i>	1.3	0.6	1.7%	17	4.3	2.3	4.5%	45
DHW (+ HVAC)	<i>kBtu/sf</i>	20.5	11.8	21.9%	219	21.0	14.2	15.9%	159
		39.59	30.25			43.11	34.29		
			23.6%				20.5%		

\*Note: Pumps are less than 0.01 EUI and not shown here with the resolution of these results

## School-Primary

		school-primary				school-primary			
		CZ4C	CZ4C			CZ5B	CZ5B		
		gas	hp	Site Savings (%)	Site Savings EUI	gas	hp	Site Savings (%)	Site Savings EUI
Equipment Int.	<i>kBtu/sf</i>	19.3	19.3	0%	0.0	19.3	19.3	0%	0.0
Equipment Ext.	<i>kBtu/sf</i>	0.2	0.2	0%	0.0	0.2	0.2	0%	0.0
Equipment Refrig.	<i>kBtu/sf</i>	0.8	0.8	0%	0.0	0.8	0.8	0%	0.0
Lighting Int.	<i>kBtu/sf</i>	3.2	3.2	0%	0.0	3.2	3.2	0%	0.0
Lighting Ext.	<i>kBtu/sf</i>	0.4	0.4	0%	0.0	0.4	0.4	0%	0.0
Fans	<i>kBtu/sf</i>	3.4	3.5	-1%	0.0	3.8	4.0	-6%	0.2
Pumps*	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Cooling	<i>kBtu/sf</i>	1.6	1.6	0%	0.0	2.4	2.3	0%	0.0
Space Heat, Gas	<i>kBtu/sf</i>	1.6	0.0	100%	-1.6	3.6	0.0	100%	-3.6
Space Heat, Elec	<i>kBtu/sf</i>	0.0	0.5	-7199%	0.5	0.0	1.7	-10329%	1.7
DHW, Gas	<i>kBtu/sf</i>	2.2	0.0	100%	-2.2	2.2	0.0	100%	-2.2
DHW, Elec	<i>kBtu/sf</i>	0.0	1.5	0%	1.5	0.0	1.7	0%	1.7
BACK CHECK EUI		32.8	31.1	5%	-1.7	35.9	33.7	6%	-2.3
<b>TOTAL</b>	<b><i>kBtu/sf</i></b>	<b>32.8</b>	<b>31.1</b>	<b>5%</b>	<b>-1.7</b>	<b>35.9</b>	<b>33.7</b>	<b>6%</b>	<b>-2.3</b>
		Site Energy: Gas	Site Energy: Elec	Energy Savings (% site)	Additional Credits	Site Energy: Gas	Site Energy: Elec	Energy Savings (% site)	Additional Credits
Equipment	<i>kBtu/sf</i>	20.3	20.3			20.3	20.3		
Lighting	<i>kBtu/sf</i>	3.6	3.6			3.6	3.6		
Space Heating	<i>kBtu/sf</i>	1.6	0.5	3.3%	33	3.7	1.7	5.4%	54
DHW (+ HVAC)	<i>kBtu/sf</i>	7.2	6.6	2.0%	20	8.3	8.0	1.0%	10
		32.78	31.06			35.93	33.66		
			5.3%				6.3%		

\*Note: Pumps are less than 0.01 EUI and not shown here with the resolution of these results

## Retail Stand Alone

		retail-standalone				retail-standalone			
		CZ4C	CZ4C			CZ5B	CZ5B		
		gas	hp	Site Savings (%)	Site Savings EUI	gas	hp	Site Savings (%)	Site Savings EUI
Equipment Int.	<i>kBtu/sf</i>	7.5	7.5	0%	0.0	7.5	7.5	0%	0.0
Equipment Ext.	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Equipment Refrig.	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Lighting Int.	<i>kBtu/sf</i>	8.6	8.6	0%	0.0	8.7	8.7	0%	0.0
Lighting Ext.	<i>kBtu/sf</i>	1.6	1.6	0%	0.0	1.6	1.6	0%	0.0
Fans	<i>kBtu/sf</i>	3.3	3.3	-1%	0.0	3.6	3.8	-6%	0.2
Pumps	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Cooling	<i>kBtu/sf</i>	1.4	1.4	-1%	0.0	2.0	2.0	-1%	0.0
Space Heat, Gas	<i>kBtu/sf</i>	4.6	0.0	100%	-4.6	9.7	0.0	100%	-9.7
Space Heat, Elec	<i>kBtu/sf</i>	0.0	1.6	0%	1.6	0.0	4.2	0%	4.2
DHW, Gas	<i>kBtu/sf</i>	3.6	0.0	100%	-3.6	3.6	0.0	100%	-3.6
DHW, Elec	<i>kBtu/sf</i>	0.0	1.0	0%	1.0	0.0	1.0	0%	1.0
BACK CHECK EUI		30.7	25.1	18%	-5.6	36.7	28.8	22%	-7.9
<b>TOTAL</b>	<b><i>kBtu/sf</i></b>	<b>30.6</b>	<b>25.1</b>	<b>18%</b>	<b>-5.6</b>	<b>36.7</b>	<b>28.8</b>	<b>22%</b>	<b>-7.9</b>
		Site Energy: Gas	Site Energy: Elec	Energy Savings (% site)	Additional Credits	Site Energy: Gas	Site Energy: Elec	Energy Savings (% site)	Additional Credits
Equipment	<i>kBtu/sf</i>	7.5	7.5			7.5	7.5		
Lighting	<i>kBtu/sf</i>	10.3	10.3			10.3	10.3		
Space Heating	<i>kBtu/sf</i>	4.6	1.6	9.8%	98	9.7	4.2	14.9%	149
DHW (+ HVAC)	<i>kBtu/sf</i>	8.3	5.7	8.3%	83	9.2	6.8	6.6%	66
		30.65	25.09			36.69	28.80		
			18.1%				21.5%		

## Warehouse

		warehouse				warehouse			
		CZ4C	CZ4C			CZ5B	CZ5B		
		gas	hp	Site Savings (%)	Site Savings EUI	gas	hp	Site Savings (%)	Site Savings EUI
Equipment Int.	<i>kBtu/sf</i>	2.5	2.5	0%	0.0	2.5	2.5	0%	0.0
Equipment Ext.	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Equipment Refrig.	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Lighting Int.	<i>kBtu/sf</i>	1.9	1.9	0%	0.0	1.9	1.9	0%	0.0
Lighting Ext.	<i>kBtu/sf</i>	1.2	1.2	0%	0.0	1.2	1.2	0%	0.0
Fans	<i>kBtu/sf</i>	0.4	0.4	-2%	0.0	0.5	0.6	-11%	0.1
Pumps	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Cooling	<i>kBtu/sf</i>	0.1	0.1	-11%	0.0	0.1	0.1	-5%	0.0
Space Heat, Gas	<i>kBtu/sf</i>	2.2	0.0	100%	-2.2	7.6	0.0	100%	-7.6
Space Heat, Elec	<i>kBtu/sf</i>	0.0	1.0	0%	1.0	0.0	4.7	0%	4.7
DHW, Gas	<i>kBtu/sf</i>	0.5	0.0	100%	-0.5	0.5	0.0	100%	-0.5
DHW, Elec	<i>kBtu/sf</i>	0.0	0.2	0%	0.2	0.0	0.2	0%	0.2
BACK CHECK EUI		8.8	7.4	16%	-1.4	14.4	11.3	22%	-3.1
<b>TOTAL</b>	<b><i>kBtu/sf</i></b>	<b>8.8</b>	<b>7.4</b>	<b>16%</b>	<b>-1.4</b>	<b>14.4</b>	<b>11.3</b>	<b>22%</b>	<b>-3.1</b>
		Site Energy: Gas	Site Energy: Elec	Energy Savings (% site)	Additional Credits	Site Energy: Gas	Site Energy: Elec	Energy Savings (% site)	Additional Credits
Equipment	<i>kBtu/sf</i>	2.5	2.5			2.5	2.5		
Lighting	<i>kBtu/sf</i>	3.1	3.1			3.1	3.1		
Space Heating	<i>kBtu/sf</i>	2.2	1.0	13.4%	134	7.6	4.7	20.0%	200
DHW (+ HVAC)	<i>kBtu/sf</i>	1.0	0.7	2.8%	28	1.2	0.9	1.7%	17
		8.81	7.38			14.38	11.25		
			16.3%				21.8%		

## Hotel Small

		Hotel Small				Hotel Small			
		CZ4C				CZ5B			
		gas	hp	Site Savings (%)	Site Savings EUI	gas	hp	Site Savings (%)	Site Savings EUI
Equipment Int.	<i>kBtu/sf</i>	22.2	22.2	0%	0.0	22.2	22.2	0%	0.0
Equipment Ext.	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Equipment Refrig.	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Lighting Int.	<i>kBtu/sf</i>	3.6	3.6	0%	0.0	3.6	3.6	0%	0.0
Lighting Ext.	<i>kBtu/sf</i>	0.9	0.9	0%	0.0	0.9	0.9	0%	0.0
Fans	<i>kBtu/sf</i>	6.4	6.4	0%	0.0	7.3	7.3	0%	0.0
Pumps	<i>kBtu/sf</i>	0.0	0.0	0%	0.0	0.0	0.0	0%	0.0
Cooling	<i>kBtu/sf</i>	5.7	5.5	4%	-0.2	5.6	5.3	5%	-0.3
Space Heat, Gas	<i>kBtu/sf</i>	0.6	0.0	100%	-0.6	1.3	0.0	100%	-1.3
Space Heat, Elec	<i>kBtu/sf</i>	0.8	1.0	-25%	0.2	2.1	2.7	-30%	0.6
DHW, Gas	<i>kBtu/sf</i>	22.0	0.0	100%	-22.0	22.0	0.0	100%	-22.0
DHW, Elec	<i>kBtu/sf</i>	0.0	10.0	0%	10.0	0.0	9.1	0%	9.1
BACK CHECK EUI		62.3	49.7	20%	-12.6	65.1	51.2	21%	-13.9
<b>TOTAL</b>	<b><i>kBtu/sf</i></b>	<b>62.3</b>	<b>49.7</b>	<b>20%</b>	<b>-12.6</b>	<b>65.1</b>	<b>51.2</b>	<b>21%</b>	<b>-13.9</b>
		Site Energy: Gas	Site Energy: Elec	Energy Savings (% site)	Additional Credits	Site Energy: Gas	Site Energy: Elec	Energy Savings (% site)	Additional Credits
Equipment	<i>kBtu/sf</i>	22.2	22.2			22.2	22.2		
Lighting	<i>kBtu/sf</i>	4.6	4.6			4.5	4.5		
Space Heating	<i>kBtu/sf</i>	1.3	1.0	0.6%	6	3.4	2.7	1.1%	11
DHW (+ HVAC)	<i>kBtu/sf</i>	34.2	21.9	19.6%	196	34.9	21.7	20.2%	202
		62.27	49.69			65.08	51.20		
			20.2%				21.3%		

## Appendix 2: Energy Modeling Key Inputs for Efficiency

MODEL EFFICIENCY INPUTS			
<b>Office Medium</b>			
<b>Office Medium</b> Electric Heating Scenario <i>Space Heating</i> <i>Central Heat Pump and HR Chillers</i> Table C403.3.2(15) Air Source HP, OA DB 47F (CZ4C)	<b>Office Medium</b> Gas Heating Scenario <i>Space Heating</i> Central Boiler Table 403.3.2(6) Boiler, hot water Capacity Range, BTU/h		
Medium HW, 120 F Capacity Range, BTU/h	any	300,000 to 2,500,000 Btu/h	
Model Compressor, COP	2.77	Efficiency Modeled	84%
Air Source HP, OA DB 17F (CZ5B) Medium HW, 120 F Model Compressor, COP	1.95		
<i>Domestic Hot Water</i> Central HPWH Model Compressor, COP	2.31 or 1.63 by CZ	<i>Domestic Hot Water</i> Central Boiler  Modeled Efficiency	80%
<b>Apartment Midrise</b>			
<b>Apartment Midrise</b> Electric Heating Scenario <i>Space Heating,</i> <i>apartments only shown</i>  <i>Air Cooled Unitary Heat Pumps</i> Table 403.3.2(2) Capacity Range, BTU/h	<65000	<b>Apartment Midrise</b> Gas Heating Scenario <i>Space Heating,</i> <i>apartments only shown</i> Air Cooled Unitary with Furnace Table 403.3.2(5) Capacity Range, BTU/h	any
Split System, three phase Efficiency, HSPF	7.5	Warm Air Duct Furnace Efficiency, Ec	80%
Model Compressor, COP <small><math>COP_{heat} = -0.0296 \times HSPF^2 + 0.7134 \times HSPF</math></small>	3.69	Modeled Efficiency	80%
<i>Domestic Hot Water</i> Central HPWH	2.31 or 1.63	<i>Domestic Hot Water</i> In-Unit Gas	
Model System, COP	by CZ	Modeled Efficiency	80%
<b>School Primary</b>			
<b>School Primary</b> Electric Heating Scenario <i>Space Heating</i>  <i>Air Cooled Unitary Heat Pumps</i> Table 403.3.2(2) Capacity Range, BTU/h	<65000	<b>School Primary</b> Gas Heating Scenario <i>Space Heating</i> Air Cooled Unitary with Furnace Table 403.3.2(5) Capacity Range, BTU/h	any
Single Packaged, three phase Efficiency, HSPF	6.7	Warm Air Duct Furnace Efficiency, Ec	80%
Model Compressor, COP <small><math>COP_{heat} = -0.0296 \times HSPF^2 + 0.7134 \times HSPF</math></small>	3.45	Modeled Efficiency	80%
<i>Domestic Hot Water</i> Central HPWH		<i>Domestic Hot Water</i> Gas Stand Alone Unit	

Model System, COP	2.31 or 1.63 by CZ	Modeled Efficiency	80%
<b>Warehouse</b>			
<b>Warehouse</b> Electric Heating Scenario <i>Space Heating</i>		<b>Warehouse</b> Gas Heating Scenario <i>Space Heating</i>	
<i>Air Cooled Unitary Heat Pumps</i> Table 403.3.2(2)		<i>Air Cooled Unitary with Furnace</i> Table 403.3.2(5)	
Capacity Range, BTU/h	<65000	Capacity Range, BTU/h	any
Single Packaged, three phase		Warm Air Duct Furnace	
Efficiency, HSPF	6.7	Efficiency, Ec	80%
Model Compressor, COP	3.45	Modeled Efficiency	80%
<i>COP<sub>heat</sub> = -0.0296 x HSPF<sup>2</sup> + 0.7134 x HSPF</i>			
<i>Domestic Hot Water</i> Unitized HPWH		<i>Domestic Hot Water</i> Unitized gas water heater	
Model System, COP	2.24	Modeled Efficiency	80%
<b>Retail Stand Alone</b>			
<b>Retail</b> Electric Heating Scenario <i>Space Heating</i>		<b>Retail</b> Gas Heating Scenario <i>Space Heating</i>	
<i>Air Cooled Unitary Heat Pumps</i> Table 403.3.2(2)		<i>Air Cooled Unitary with Furnace</i> Table 403.3.2(5)	
Capacity Range, BTU/h	<65000	Capacity Range, BTU/h	any
Single Packaged, three phase		Warm Air Duct Furnace	
Efficiency, HSPF	6.7	Efficiency, Ec	80%
Model Compressor, COP	3.45	Modeled Efficiency	80%
<i>COP<sub>heat</sub> = -0.0296 x HSPF<sup>2</sup> + 0.7134 x HSPF</i>			
<i>Domestic Hot Water</i> Unitized HPWH		<i>Domestic Hot Water</i> Unitized gas water heater	
Model System, COP	2.24	Modeled Efficiency	80%
<b>Hotel Small</b>			
<b>Hotel Motel (Small)</b> Electric Heating Scenario <i>Space Heating</i>		<b>Hotel Motel (Small)</b> Gas Heating Scenario <i>Space Heating</i>	
<i>Air Cooled Unitary Heat Pumps</i> Table 403.3.2(2)		<i>Air Cooled Unitary with Furnace</i> Table 403.3.2(5)	
Capacity Range, BTU/h	<65000	Capacity Range, BTU/h	any
Single Packaged, three phase		Warm Air Duct Furnace	
Efficiency, HSPF	6.7	Efficiency, Ec	80%
Model Compressor, COP	3.45	Modeled Efficiency	80%
<i>COP<sub>heat</sub> = -0.0296 x HSPF<sup>2</sup> + 0.7134 x HSPF</i>			
<i>Domestic Hot Water</i> Central HPWH		<i>Domestic Hot Water</i> Central Gas	
Model System, COP	2.31 or 1.63 by CZ	Modeled Efficiency	80%