## **Proposed Changes to Proposal 21-GP3-037**

L. Rosenow - Evergreen Technology Consulting, September 2023

**C401.3.3 Additional efficiency credits.** The number of additional efficiency credits required by Table C406.1 shall be increased by the number required in Table C401.3.3, modified as permitted in this section, and is in addition to the energy efficiency credits and load management credits required by Section C406.

Table C401.3.3

| TUNIC CTOLISIS   |            |                 |            |           |           |           |           |
|--|------------|-----------------|------------|-----------|-----------|-----------|-----------|
| Additional Credits Required  |            |                 |            |           |           |           |           |
|  |            | Occupancy Group |            |           |           |           |           |
|  | Applicable |                 |            |           |           |           |           |
| Measure Title  | Section    | Group R-1       | Group R-2  | Group B   | Group E   | Group M   | All Other |
| New building – Additional efficiency credits required for space heating systems using the fossil fuel pathway      | C401.3.3.1 | 7               | 24         | 101       | 38        | 111       | 56        |
| New building – Additional efficiency credits required for space heating systems using the fossil fuel pathway      | C401.3.3.2 | 198             | 212        | 27        | 17        | 79        | 107       |
| Building addition – Additional efficiency credits required for space heating systems using the fossil fuel pathway | C401.3.3.1 | <u>4</u>        | <u>12</u>  | <u>51</u> | <u>19</u> | <u>56</u> | <u>28</u> |
| Building addition – Additional efficiency credits required for space heating systems using the fossil fuel pathway | C401.3.3.2 | <u>99</u>       | <u>106</u> | <u>14</u> | <u>9</u>  | <u>40</u> | <u>54</u> |

Exceptions to space heating additional efficiency credit requirements in Section C401.3.3:

- Low energy spaces in accordance with Section C402.1.1.1 and equipment buildings in accordance with Section C402.1.2 that are served by space heating systems, unconditioned spaces, open parking garages, and enclosed parking garages that comply with sufficient measures from Table C406.2 C401.3.3 to achieve a minimum of 50 percent of the additional efficiency credits required.
- 2. Building additions that have less than 1,000 square feet of conditioned floor area and that comply with sufficient measures from Table C406.2 C401.3.3 to achieve a minimum of 50 percent of the additional efficiency credits required for additions.

- 3. Semi-heated spaces in accordance with Section C402.1.1.2 that comply with sufficient measures from Table C401.3.3 to achieve a minimum of 50% percent of the space heating additional efficiency credits required.
- 4. <u>Unconditioned spaces, open parking garages and unheated enclosed parking garages.</u>