

Alternative automatic fire-extinguishing systems. Option #1

904.1.1 Certification of service personnel for alternative fire-extinguishing equipment. Service personnel performing system design, installation, or conducting system maintenance, programming or testing on automatic fire-extinguishing systems, other than automatic sprinkler systems, shall possess the appropriate ICC/NAFED certification.

Formatted: Highlight

Formatted: Highlight

904.1.1.1 Pre-engineered kitchen fire-extinguishing systems. A current ICC/NAFED certification for pre-engineered kitchen fire-extinguishing systems is required when performing design, installation, inspection/testing or maintenance on kitchen suppression systems.

904.1.1.2 Engineered fire suppression systems. A current ICC/NAFED certification for engineered fire suppression systems is required when performing design, installation, inspection/testing or maintenance on kitchen suppression systems.

904.1.1.3 Preengineered industrial fire-extinguishing system. A current ICC/NAFED certification for preengineered industrial fire-extinguishing system is required when performing design, installation, inspection/testing or maintenance on kitchen suppression systems.

904.1.1 (Effective July 1, 2024) Certification of personnel for alternative fire-extinguishing equipment. Personnel performing system design, installation, maintenance, programming or testing on automatic fire-extinguishing systems, other than automatic sprinkler systems, shall possess the appropriate National Institute for Certification in Engineering Technologies (NICET) *Special Hazards Suppression Systems* certification.

Exception: A current ICC/NAFED renewed certification for pre-engineered kitchen fire extinguishing system technician is allowed in lieu of NICET Level II or higher in *Special Hazards Suppression Systems* for the design, installation, inspection/testing or maintenance on pre-engineered kitchen suppression systems.

Formatted: Highlight

Exception: A current ICC/NAFED renewed certification for pre-engineered industrial fire extinguishing systems is allowed in lieu of NICET Level II or higher in *Special Hazards Suppression Systems* for the design, installation, inspection/testing or maintenance on pre-engineered dry chemical fire extinguishing systems.

Formatted: Highlight

904.1.1.1 (Effective July 1, 2024) Design. All construction documents shall be reviewed by a NICET Level III in special hazard suppression systems or a licensed professional engineer (PE) in the state of Washington prior to being submitted for permitting. The reviewing professional shall submit a stamped, signed, and dated letter; or a verification method approved by the *fire code official* indicating the system has been reviewed and meets or exceeds the design requirements of the state of Washington and the local jurisdiction.

904.1.1.2 (Effective July 1, 2024) Installation. Installation not defined as "electrical construction trade" by chapter [19.28](#) RCW or "Fire Protection Sprinkler Fitting" by chapter [18.270](#) RCW, shall be completed by or directly supervised by a NICET Level II

or higher in *special hazards suppression systems*. Supervision shall consist of a person being on the same job site and under the control of a NICET Level II or higher in *special hazards suppression systems*.

904.1.1.3 (Effective July 1, 2024) Testing/maintenance. Inspection, testing, commissioning, maintenance, and programming not defined as "electrical construction trade" by chapter **19.28** RCW or "Fire Protection Sprinkler Fitting" by chapter **18.270** RCW, shall be completed by a NICET Level II or higher in *special hazards suppression systems*.

904.13 Commercial cooking systems. The automatic fire-extinguishing system for commercial cooking systems shall be of a type recognized for protection of commercial cooking equipment and exhaust systems of the type and arrangement protected. Pre-engineered automatic dry- and wet-chemical extinguishing systems shall be tested in accordance with UL 300 and *listed* and *labeled* for the intended application. Other types of automatic fire-extinguishing systems shall be *listed* and *labeled* for specific use as protection for commercial cooking operations. The system shall be installed in accordance with this code, NFPA 96, its listing and the manufacturer's installation instructions. Additional protection is not required for ductwork beyond 75 feet (22,860 mm) when hood suppression system complies with UL 300. Signage shall be provided on the exhaust hood or system cabinet, indicating the type and arrangement of cooking appliances protected by the automatic fire-extinguishing system. Signage shall indicate appliances from left to right, be durable, and the size, color, and lettering shall be approved. Automatic fire-extinguishing systems of the following types shall be installed in accordance with the referenced standard indicated, as follows:

1. Carbon dioxide extinguishing systems, NFPA 12.
2. *Automatic sprinkler systems*, NFPA 13.
3. Automatic water mist systems, NFPA 750.
4. Foam-water sprinkler system or foam-water spray systems, NFPA 16.
5. Dry-chemical extinguishing systems, NFPA 17.
6. Wet-chemical extinguishing systems, NFPA 17A.

Exceptions:

1. Factory-built commercial cooking recirculating systems that are tested in accordance with UL 710B and listed, labeled and installed in accordance with Section 304.1 of the *International Mechanical Code*.
2. Protection of duct systems beyond 75 feet (22,860 mm) when the commercial kitchen exhaust hood is protected by a system listed in accordance with UL 300.

Alternative automatic fire-extinguishing systems. Option #2

904.1.1 Certification of service personnel for alternative fire-extinguishing equipment. Service personnel performing system design, installation, or conducting system maintenance, programming or testing on automatic fire-extinguishing systems, other than automatic sprinkler systems, shall possess the appropriate ICC/NAFED certification.

Formatted: Highlight

Formatted: Highlight

904.1.1.1 Pre-engineered kitchen fire-extinguishing systems. A current ICC/NAFED certification for pre-engineered kitchen fire-extinguishing systems is required when performing design, installation, inspection/testing or maintenance on kitchen suppression systems.

904.1.1.2 Engineered fire suppression systems. A current ICC/NAFED certification for engineered fire suppression systems is required when performing design, installation, inspection/testing or maintenance on kitchen suppression systems.

904.1.1.3 Pre-engineered industrial fire-extinguishing system. A current ICC/NAFED certification for pre-engineered industrial fire-extinguishing system is required when performing design, installation, inspection/testing or maintenance on kitchen suppression systems.

904.1.1 (Effective January July 1, 20245) Certification of personnel for alternative fire-extinguishing equipment. Personnel performing system design, installation, maintenance, programming or testing on automatic fire-extinguishing systems, other than automatic sprinkler systems, shall possess the appropriate National Institute for Certification in Engineering Technologies (NICET) *Special Hazards Suppression Systems* certification.

Exception: A current ICC/NAFED **Renewed** certification for pre-engineered kitchen fire extinguishing system technician is allowed in lieu of NICET Level II or higher in *Special Hazards Suppression Systems* for the design, installation, inspection/testing or maintenance on pre-engineered kitchen suppression systems.

Formatted: Highlight

904.1.1.1 (Effective January July 1, 20245) Design. All construction documents shall be reviewed by a NICET Level III in special hazard suppression systems or a licensed professional engineer (PE) in the state of Washington prior to being submitted for permitting. The reviewing professional shall submit a stamped, signed, and dated letter; or a verification method approved by the *fire code official* indicating the system has been reviewed and meets or exceeds the design requirements of the state of Washington and the local jurisdiction.

904.1.1.2 (Effective January July 1, 20245) Installation. Installation not defined as "electrical construction trade" by chapter **19.28** RCW or "Fire Protection Sprinkler Fitting" by chapter **18.270** RCW, shall be completed by or directly supervised by a NICET Level II or higher in *special hazards suppression systems*. Supervision shall consist of a person being on the same job site and under the control of a NICET Level II or higher in *special hazards suppression systems*.

904.1.1.3 (Effective ~~January~~ July 1, 2024⁵) Testing/maintenance. Inspection, testing, commissioning, maintenance, and programming not defined as "electrical construction trade" by chapter **19.28** RCW or "Fire Protection Sprinkler Fitting" by chapter **18.270** RCW, shall be completed by a NICET Level II or higher in *special hazards suppression systems*.

904.13 Commercial cooking systems. The automatic fire-extinguishing system for commercial cooking systems shall be of a type recognized for protection of commercial cooking equipment and exhaust systems of the type and arrangement protected. Pre-engineered automatic dry- and wet-chemical extinguishing systems shall be tested in accordance with UL 300 and *listed and labeled* for the intended application. Other types of automatic fire-extinguishing systems shall be *listed and labeled* for specific use as protection for commercial cooking operations. The system shall be installed in accordance with this code, NFPA 96, its listing and the manufacturer's installation instructions. Additional protection is not required for ductwork beyond 75 feet (22,860 mm) when hood suppression system complies with UL 300. Signage shall be provided on the exhaust hood or system cabinet, indicating the type and arrangement of cooking appliances protected by the automatic fire-extinguishing system. Signage shall indicate appliances from left to right, be durable, and the size, color, and lettering shall be approved. Automatic fire-extinguishing systems of the following types shall be installed in accordance with the referenced standard indicated, as follows:

1. Carbon dioxide extinguishing systems, NFPA 12.
2. *Automatic sprinkler systems*, NFPA 13.
3. Automatic water mist systems, NFPA 750.
4. Foam-water sprinkler system or foam-water spray systems, NFPA 16.
5. Dry-chemical extinguishing systems, NFPA 17.
6. Wet-chemical extinguishing systems, NFPA 17A.

Exceptions:

1. Factory-built commercial cooking recirculating systems that are tested in accordance with UL 710B and listed, labeled and installed in accordance with Section 304.1 of the *International Mechanical Code*.
2. Protection of duct systems beyond 75 feet (22,860 mm) when the commercial kitchen exhaust hood is protected by a system listed in accordance with UL 300.