

| Significant Changes | | | | | |
|---------------------|---|---|----------------|------------------------|------------------------------|
| 2024 Code Section | Title or Subject | Reviewer Comments | Cost Yes/No | Amend Needed Yes/No | TAG Comments/Recommendations |
| TAG Member: | Lia Sommer | IEBC 07 ALTERATIONS—LEVEL 1 | | | |
| 702 | BUILDING ELEMENTS AND MATERIALS | Editorial change, clarification. | | | |
| 702.5 | Replacement window for emergency escape and rescue openings | Language already in 2021 IEBC "The replacement window shall be permitted to be of the same operating style as the existing window or a style that provides for an equal or greater window opening area than the existing window." | | | |
| 705.1 | General | Align with 2024 IBC new code section 1608.3 Ponding instability and 1611.2 Ponding instability | | | |
| 705.2 | Roof replacement | New language added, clarify roof replacement requirements when existing self-adhered underlayment is involved | | | |
| 706 | STRUCTURAL | Align with language in IEBC 304.3.2 | | | |