

Significant Changes

2024 Code Section	Title or Subject	Reviewer Comments	Cost Yes/No	Amend Needed Yes/No	TAG Comments/Recommendations
TAG Member:	Lia Sommer	IEBC 08 ALTERATIONS—LEVEL 2			
803.2	Automatic sprinkler systems	Editorial change, clarification.			
803.4.3	Installation	<p>New language: 803.4.3 Installation. Where a fire alarm system is required to be installed in accordance with Sections 803.4.1 or 803.4.2, the fire alarm system shall be installed in accordance with the provisions of this code, Section 907 of the International Building Code and NFPA 72.</p> <p>Table 804.5.1.1(1) Basement, first, second or third story above grade plane and occupiable roofs over the first or second floor above grade plane for R-2 increased from 50' to 125'; Table 804.5.1.1(2) First story above or below grade plane or occupiable roofs over the first story above grade plane for occupancy B,F-2 increased from 35 to 49</p>			
804	MEANS OF EGRESS Existing structural elements				
805.3	resisting lateral loads	New language added in the section			