

Significant Changes

2024 Code Section	Title or Subject	Reviewer Comments	Cost Yes/No	Amend Needed Yes/No	TAG Comments/Recommendations
TAG Member:	Lia Sommer	IEBC 10 Change of Occupancy			
1001	GENERAL Change of occupancy in health	Editorial change			
1002.3	care	New exception for I-1 occupancy			
1004	FIRE PROTECTION	Editorial change			
1006	STRUCTURAL	New language added in the section			
		New section 1011.2.1.1 Nonrequired automatic sprinkler systems. Clarify requirements for non-required automatic sprinkler systems; option to remove with approval of code official.			
1011.2	Fire protection systems				
1011.5	Means of egress, general	New exception for I occupancy			
	Height and area for change to a				
1011.6.1	higher-hazard category	New exception			