

Significant Changes

2024 Code Section	Title or Subject	Reviewer Comments	Cost Yes/No	Amend Needed Yes/No	TAG Comments/Recommendations
TAG Member:	Lia Sommer	IEBC 11 Additions			

1101	GENERAL	New section 1101.3 Risk category assignment and 1101.6 Smoke barriers in Group I-1, Condition 2			
1102.3	Fire protection systems	Added exception: Nonoccupiable appendages, such as elevator and exit stairway shafts, shall be permitted beyond that permitted by the International Building Code.			
1103.2	Lateral force-resisting system	New language added in the section			