

IFC Significant Changes					
2024 Code Section	Title or Subject	Reviewer Comments	Cost Yes/No	Amend Needed Yes/No	TAG Comments/Recommendations
	Elevators, escalators and moving walks	Keep state amendment of adding in exception of: 2. Escalators used as a means of egress for fixed transit and passenger rail systems in accordance with Section 4901	N	Y	
	1003.7	Delete state amendment. Model code has same language.	N	Y	
	1004.5 Areas without fixed seating.	Delete state amendment. Model code has same language	N	Y	
1004.5.1	Increased occupant load.	Keep state amendment.	N	Y	
Table 1004.5	Maximum Floor Area Allowances Per Occupant.	Keep state amendment that adds exception 2: 2. The capacity in inches, of means of egress components for fixed guideway transit and passenger rail stations, shall meet the requirements of Section 4901.	N	Y	
	1005.1 General.	Keep state amendment that adds exception 4. 4. The common path of travel for fixed transit and passenger rail system stations shall be in accordance with Section 4901.	N	Y	
1006.2.1	Egress based on occupant load and common path of egress travel distance.	Keep state amendment that adds exception of: EXCEPTION:The number of required exits for fixed transit and passenger rail systems may be reduced by one at open stations.	N	Y	
1006.2.1.1	Three or more exits or exit access doorways.	I do not think the State amendment is needed. 2024 code changes occupied to occupiable roof. State amendment deletes this entire section: <del>Exception: Illumination shall be provided along the path of travel for the exit discharge from each exit to the public way.</del> 4. The path of exit discharge is illuminated from the exit to a safe dispersal area complying with Section 1028.5. 2. A dispersal area shall be illuminated to a level not less than 1 footcandle (11 lux) at the walking surface.	N	Y	
1006.3.4	Single exits.	I do not think the State amendment is needed. 2024 code changes occupied to occupiable roof. State amendment deletes this entire section: <del>Exception: Illumination shall be provided along the path of travel for the exit discharge from each exit to the public way.</del> 4. The path of exit discharge is illuminated from the exit to a safe dispersal area complying with Section 1028.5. 2. A dispersal area shall be illuminated to a level not less than 1 footcandle (11 lux) at the walking surface.	N	N?	
1008.2.3	Exit discharge.	Keep state amendment that adds exception 3 of:	N	Y	
	Accessible means of egress	3. In parking garages, accessible means of egress are not required to serve parking areas that do not contain accessible parking spaces.	N	Y	
1009.1	required.	This does not seem to be needed, Delete the State amendment.	N	Y	
1009.8	Two-way communication	Keep state amendment but modify because of new language in 2024. Added: The two-way communication system shall have a battery backup or an approved alternate source of power that is capable of 90 minutes use upon failure of the normal power source.	N	N?	
1009.8.1	System requirements.	Keep state amendment but modify because of new language in 2024 including new Table 1010.2.4. This section needs worked over, they added I-1, added language to Group A, Manual bolts Single exit doors.	Y	Y	
1010.2.4	Locks and latches.	Delete amendment. Matches 2024 IFC.	Y	Y	
1010.2.13	Security grilles.	Keep state amendment of "In fixed transit and passenger rail system stations horizontal and vertical security grilles are permitted at station entrances as a component in the means of egress when the station is under constant supervision by on-site security personnel and an exit door with panic hardware that swings in the direction of egress, with a minimum clear width of 32 inches (813 mm), provided within 10 feet of the gate. The security grilles shall remain secured in the full-open position during the period of occupancy by the general public."	N	Y	
1010.3.4.1	Fixed transit and passenger rail systems.	Keep state amendment of "Stairs or ladders within an individual dwelling unit used for access to areas of 200 square feet (18.6 m2) or less, and not containing the primary bathroom or kitchen, are exempt from the requirements of Section 1009."	Y	Y	
	Stairways in individual dwelling	Keep state amendment. See word Doc.	Y	Y	
1011.17	units.	Keep state amendment but review new language in 2024 IFC.	Y	Y	
1012.1	Scope	Keep state amendment but review new language in 2024 IFC.	Y	Y	
1014.2	Height and location.	Delete state amendment because in 2024 IFC. May need to revisit above numbering.	Y	Y	
1014.2.1	Height	Keep State amendments	Y	Y	
1014.2.2	Lateral location	Delete State amendment	Y	Y	
1014.9	Projections	Delete State amendment	Y	Y	
1015.2	Where required	Delete State amendment	Y	Y	
1015.3	Height	Keep existing state amendment and modify Table with new 2024 IFC language & footnote.	Y	Y	
Table 1017.2	Exit Access Travel Distance	Keep existing state amendment, add to word doc.	Y	Y	
1020.6	Air movement in corridors.	Keep existing state amendments that adds the following: "Where interior exit stairways and ramps are pressurized in accordance with Section 909.20.5 of the International Building Code, the smoke control pressurization system shall comply with the requirements specified in Section 909.6.3 of the International Building Code."	Y	Y	
1023.12	Smokeproof enclosures		Y	Y	