

Significant Changes

| 2024 Code Section | Title or Subject | Reviewer Comments | Cost Yes/No | Amend Needed Yes/No | TAG Comments/Recommendations |
|-------------------|---|---|----------------|------------------------|------------------------------|
| | | Define "Temporary", may need a definition section added or utilize and insert/adopt: 3103.4 Use period. | | | |
| 4101.1 | General | Temporary tents, air-supported, air-inflated or tensioned membrane structures shall not be erected for a period of more than 180 days within a 12-month period on a single premises or dependent on the AHJ? | No | Yes | |
| 4101.2 | Permits | New section no concerns | No | No | |
| 4101.3 | Listed equipment | New section no concerns | No | No | |
| 4101.4 | Operation and maintenance | New section no concerns | No | No | |
| 4101.4.1 | Wildfire risk area | New section no concerns | No | No | |
| 4101.4.2 | Attendance | New section no concerns | No | No | |
| 4101.4.3 | Fire extinguishers | New section no concerns | No | No | |
| 4101.6 | General | If new amendment is adopted this will need to be updated to account for my proposed 4101.6.3.1 section. | No | Yes | |
| 4101.6.4 | Refueling | New section no concerns | No | No | |
| 4101.6.4.1 | Storage | See word document for recommendation | No | Yes | |
| 4101.6.7 | Oil-fired heaters | New section no concerns | No | No | |
| 4101.8 | Refueling of flammable and combustible liquid-fueled equipment | Recommend adding "refueling" & 20ft. is consistent with 3108.13.3 Refueling requirements from tents or membran structures. | No | Yes | |
| 4101.9 | Cooking operations | See word document for recommendation | No | Yes | |
| 4101.1 | Hazard abatement | New section no concerns | No | No | |
| 4101.10.1 | Correction of unsafe conditions. | New section no concerns | No | No | |
| 4104.1 | Portable Fuel-Fired Cooking Appliances | New section no concerns | No | No | |
| 4104.3 | Indoor cooking | Consideration for storage of wood pizza ovens? | No | No | |
| 4104.4 | Cooking operations | See word document for recommendation | No | Yes | |
| 4104.5 | Seperation | New section no concerns | No | No | |
| 4105.1 | Portable electrical cooking appliances | New section no concerns | No | No | |
| 4105.1.1 | Listed and labeled | New section no concerns | No | No | |
| 4105.1.2 | Power supply | See word document for recommendation | No | No | |
| 4105.1.3 | Extension Cords | New section no concerns | No | No | |
| 4105.1.4 | Temporary connections | New section no concerns | No | No | |
| 4105.1.5 | Prohibited areas | New section no concerns | No | No | |
| 4106.1 | General | New section no concerns | No | No | |
| 4106.4 | Maintenance | New section no concerns | No | No | |
| 4106.4.1 | Exhaust systems | New section no concerns | No | No | |
| 4106.4.2 | Fire protection systems and devices | Recommend adding fire extinguisher section per 906 | No | No | |
| 4106.4.3 | Fuel gas systems | New section no concerns | No | No | |
| 4106.4.3.1 | LP-gas systems | Recommend removing this section | No | Yes | |
| 4106.4.3.3 | Annual leakage test | Recommend removing this section, see word document for recommendation. | No | Yes | |
| 4106.5 | Manual system operation for the automatic fire extinguishing systems(s) | New section no concerns | No | Yes | |
| 4106.6 | Solid fuel | Recommend new amendment to take into consideration solid fuel burning such as mobile pizza ovens located within the vehicle. Or determine if we do not allow these types of food truck to be in operation. Concerns with discarded smoldering embers. | Yes | Yes | |
| 4106.7 | Oven | Consideration for the installation requirement for wood burning ovens. UL 2126 requirements? | No | Yes | |