



STATE OF WASHINGTON
STATE BUILDING CODE COUNCIL

September 2024
Log No. _____

1. State Building Code to be Amended:

- ☒ International Building Code
- ☐ ICC ANSI A117.1 Accessibility Code
- ☐ International Existing Building Code
- ☐ International Residential Code
- ☐ International Fire Code
- ☐ Uniform Plumbing Code

- ☐ International Mechanical Code
- ☐ International Fuel Gas Code
- ☐ NFPA 54 National Fuel Gas Code
- ☐ NFPA 58 Liquefied Petroleum Gas Code
- ☐ Wildland Urban Interface Code

For the Washington State Energy Code, please see specialized [energy code forms](#)

Section(s): 1613.4 Amendments to ASCE 7

(e.g.: Section: R403.2)

Title: Removal of Voluntary Use of Multi-Period Response Spectra for Determination of Seismic Hazard

(e.g.: Footings for wood foundations)

2. Proponent Name (Specific local government, organization or individual):

Proponent: Scott Neuman, PE, SE

Title: Chair, Structural Engineers Association of Washington, Earthquake Engineering Committee

Date: 9/1/2024

3. Designated Contact Person:

Name: Scott Neuman, PE, SE

Title: Senior Structural Engineer

Address: 5204 120th Ave SE. Bellevue, WA 98006

Office Phone: None

Cell: (206) 388-8228

E-Mail address: scotneu@gmail.com

- 4. Proposed Code Amendment.** Reproduce the section to be amended by underlining all added language, striking through all deleted language. Insert new sections in the appropriate place in the code in order to continue the established numbering system of the code. If more than one section is proposed for amendment or more than one page is needed for reproducing the affected section of the code, additional pages may be attached.

Clearly state if the proposal modifies an existing amendment or if a new amendment is needed. If the proposal modifies an **existing amendment**, show the modifications to the existing amendment by underlining all added language and striking through all deleted language. If a new amendment is needed, show the modifications to the **model code** by underlining all added language and striking through all deleted language.

Code(s) International Building Code 2024 **Section(s)** 1613.4

Enforceable code language must be used.
Amend section to read as follows:

1613.4 Amendments to ASCE 7. The provisions of Section 1613.4 shall be permitted as an amendment to the relevant provisions of ASCE 7. The text of ASCE 7 shall be amended as indicated in Sections 1613.4.1 through 1613.4.2 ~~1613.4.6~~.

~~1613.4.3 ASCE 7 Section 11.2~~ Amend ASCE 7 Section 11.2 to include the following definition:

USGS SEISMIC DESIGN GEODATABASE: A US Geological Survey (USGS) database of geocoded values of seismic design parameters and geocoded sets of multi-period 5% damped risk-targeted maximum considered earthquake (MCE_R) response spectra. The parameters obtained from this database may only be used where referenced by Section 11.4.8.1.

User Note: The USGS Seismic Design Geodatabase is intended to be accessed through a USGS Seismic Design Web Service that allows the user to specify the site location, by latitude and longitude, and the site class to obtain the seismic design data. The USGS web service spatially interpolates between the gridded data of the USGS geodatabase. Both the USGS geodatabase and the USGS web service can be accessed at <https://doi.org/10.5066/F7NK3C76>. The USGS Seismic Design Geodatabase is available at the ASCE 7 Hazard Tool <https://asce7hazardtool.online/> or an approved equivalent.

~~1613.4.4 ASCE 7 Section 11.4.8~~ Amend ASCE 7 Section 11.4.8 to include the following section:

~~11.4.8.1 Multi-Period Design Response Spectrum~~

As an alternative to the ground motion hazard analysis requirements of Section 11.4.8, and suitable for all structures other than those designated Site Class F (unless exempted in accordance with Section 20.3.1), a **Multi-Period Design Response Spectrum** may be developed as follows:

1. For exclusive use with the USGS Seismic Design Geodatabase in accordance with this section, the Site Class shall be determined per Section 20.6.

2. Where a Multi-Period Design Response Spectrum is developed in accordance with this section, the parameters S_{MS} , S_{MT} , S_{DS} , S_{DT} , and T_L as obtained by the USGS Seismic Design Geodatabase shall be used for all applications of these parameters in this standard.

3. The S_S and S_T parameters obtained by the USGS Seismic Design Geodatabase are only permitted to be used in development of the Multi-Period Design Response Spectrum and are not permitted to be used in other applications in this standard. The mapped parameters S_S and S_T as determined by Section 11.4.2 and peak ground acceleration parameter PGA_M as determined by Section 11.8.3 shall be used for all other applications in this standard.

4. At discrete values of period, T , equal to 0.0 s, 0.01 s, 0.02 s, 0.03 s, 0.05 s, 0.075 s, 0.1 s, 0.15 s, 0.2 s, 0.25 s, 0.3 s, 0.4 s, 0.5 s, 0.75 s, 1.0 s, 1.5 s, 2.0 s, 3.0 s, 4.0 s, 5.0 s, 7.5 s, and 10.0 s, the 5% damped design spectral response acceleration parameter, S_a , shall be taken as 2/3 of the multi-period 5% damped MCE_R response spectrum from the USGS Seismic Design Geodatabase for the applicable site class.

5. At each response period, T , less than 10.0 s and not equal to one of the discrete values of period, T , listed in Item 4 above, S_a shall be determined by linear interpolation between values of S_a of Item 4 above.

6. At each response period, T , greater than 10.0 s, S_a shall be taken as the value of S_a at the period of 10.0 s, factored by $10/T$, where the value of T is less than or equal to that of the long-period transition period, T_L , and shall be taken as the value of S_a at the period of 10.0 s factored by $10T_L/T^2$, where the value of T is greater than that of the long-period transition period, T_L .

7. Where an MCE_R response spectrum is required, it shall be determined by multiplying the Multi-Period Design Response Spectrum by 1.5.

8. For use with the equivalent lateral force procedure, the spectral acceleration S_a at T shall be permitted to replace S_{DT}/T in Equation (12.8-3) and $S_{DT}/T_L/T^2$ in Equation (12.8-4).

1613.4.5 ASCE 7 Section 20.6 Amend ASCE 7 Chapter 20 to include the following section:

Section 20.6 Site Classification Procedure For Use With Section 11.4.8.1

For exclusive use in determining the Multi-Period Design Response Spectrum and associated spectral parameters in accordance with Section 11.4.8.1, the Site Class shall be determined in accordance with this section. For all other applications in this standard the Site Class shall be determined per Section 20.1.

20.6.1 Site Classification

The site soil shall be classified in accordance with Table 20.6-1 and Section 20.6.2 based on the average shear wave velocity parameter, \bar{v}_s , which is derived from the measured shear wave velocity profile from the ground surface to a depth of 100 ft (30 m). Where shear wave velocity is not measured, appropriate generalized correlations between shear wave velocity and standard penetration test (SPT) blow counts, cone penetration test (CPT) tip resistance, shear strength, or other geotechnical parameters shall be used

to obtain an estimated shear wave velocity profile, as described in Section 20.6.3. Where site-specific data (measured shear wave velocities or other geotechnical data that can be used to estimate shear wave velocity) are available only to a maximum depth less than 100 ft (30 m), \bar{v}_s shall be estimated as described in Section 20.6.3.

Where the soil properties are not known in sufficient detail to determine the site class, the most critical site conditions of Site Class C, Site Class CD and Site Class D, as defined in Section 20.6.2, shall be used unless the Authority Having Jurisdiction or geotechnical data determine that Site Class DE, E or F soils are present at the site. Site Classes A and B shall not be assigned to a site if there is more than 10 ft (3.1 m) of soil between the rock surface and the bottom of the spread footing or mat foundation.

20.6.2 Site Class Definitions

Site Class types shall be assigned in accordance with the definitions provided in Table 20.6.2-1 and this section.

20.6.2.1 Soft Clay Site Class E

Where a site does not qualify under the criteria for Site Class F per Section 20.3.1 and there is a total thickness of soft clay greater than 10 ft (3 m), where a soft clay layer is defined by $s_u < 500\text{psf}$ ($s_u < 25\text{ kPa}$), $w \geq 40\%$, and $PI > 20$, it shall be classified as Site Class E. This classification is made regardless of \bar{v}_s , as computed in Section 20.4.

20.6.2.2 Site Classes C, CD, D, DE and E

The assignment of Site Class C, CD, D, DE, and E soils shall be made based on the average shear wave velocity, which is derived from the site shear wave velocity profile from the ground surface to a depth of 100 ft (30 m), as described in Section 20.4.

20.6.2.3 Site Classes B and BC (Medium Hard and Soft Rock)

Site Class B can only be assigned to a site on the basis of shear wave velocity measured on site. If shear wave velocity data are not available and the site condition is estimated by a geotechnical engineer, engineering geologist, or seismologist as Site Class B or BC on the basis of site geology, consisting of competent rock with moderate fracturing and weathering, the site shall be classified as Site Class BC. Softer and more highly fractured and weathered rock shall either be measured on site for shear wave velocity or classified as Site Class C.

20.6.2.4 Site Class A (Hard Rock)

The hard rock, Site Class A, category shall be supported by shear wave velocity measurement, either on site or on profiles of the same rock type in the same formation with an equal or greater degree of weathering and fracturing. Where hard rock conditions are known to be continuous to a depth of 100 ft (30 m), surficial shear wave velocity measurements to maximum depths less than 100 ft are permitted to be extrapolated to assess \bar{v}_s .

Table 20.6.2-1 Site Classification

Site Class	\bar{v}_s Calculated Using Measured or Estimated Shear Wave Velocity Profile (ft/s)
------------	---

A. Hard Rock	$> 5,000$
B. Medium Hard Rock	$> 3,000$ to $5,000$
BC. Soft Rock	$> 2,100$ to $3,000$
C. Very Dense Sand or Hard Clay	$> 1,450$ to $2,100$
CD. Dense Sand or Very Stiff Clay	$> 1,000$ to $1,450$
D. Medium Dense Sand or Stiff Clay	> 700 to $1,000$
DE. Loose Sand or Medium Stiff Clay	> 500 to 700
E. Very Loose Sand or Soft Clay	≤ 500

20.6.3 Estimation of Shear Wave Velocity Profiles

Where measured shear wave velocity data are not available, shear wave velocity shall be estimated as a function of depth using correlations with suitable geotechnical parameters, including standard penetration test (SPT) blow counts, shear strength, overburden pressure, void ratio, or cone penetration test (CPT) tip resistance, measured at the site.

Site Class based on estimated values of \bar{v}_s shall be derived using \bar{v}_s , $\bar{v}_s/1.3$, and $1.3\bar{v}_s$ when correlation models are used to derive shear wave velocities. Where correlations derived for specific local regions can be demonstrated to have greater accuracy, factors less than 1.3 can be used if approved by the Authority Having Jurisdiction. If the different average velocities result in different Site Classes per Table 20.6.2-1, the most critical of the site classes for ground motion analysis at each period shall be used.

Where the available data used to establish the shear wave velocity profile extends to depths less than 100 ft (30 m) but more than 50 ft (15 m), and the site geology is such that soft layers are unlikely to be encountered between 50 and 100 ft, the shear wave velocity of the last layer in the profile shall be extended to 100 ft for the calculation of \bar{v}_s in Equation (20.4-1). Where the data does not extend to depths of 50 ft (15 m), default site classes, as described in Section 20.6.1, shall be used unless another site class can be justified on the basis of the site geology.

1613.4.6 ASCE 7 Section 21.3.1 Amend ASCE 7 Section 21.3 to include the following section:

Section 21.3.1 Alternate Minimum Design Spectral Response Accelerations

As an alternate approach to Section 21.3, the lower limit of S_a is permitted to be determined according to this section. The design spectral response acceleration at any period shall not be taken less than 80% of the Multi-Period Design Response Spectrum as determined by Section 11.4.8.1.

For sites classified as Site Class F requiring site-specific analysis in accordance with Section 11.4.8, the design spectral response acceleration at any period shall not be less than 80% of S_a determined for Site Class E.

EXCEPTION: Where a different site class can be justified using the site-specific classification procedures in accordance with Section 20.6.2.2, a lower limit of 80% of S_a for the justified site class shall be permitted to be used.

5. **Briefly explain your proposed amendment, including the purpose, benefits and problems addressed.** Specifically note any impacts or benefits to business, and specify construction types, industries and services that would be affected. Finally, please note any potential impact on enforcement such as special reporting requirements or additional inspections required.

During the previous code cycle, the Structural Engineers Association of Washington (SEAW) Earthquake Engineering Committee (EEC) put forward a code amendment that would bring forward the Multi-Period Response Spectrum (MPRS) procedure from ASCE 7-22 into the 2021 IBC with Washington State Code Amendments. This proposal both simplified complexities in ASCE 7-16 and allowed use of the MPRS procedure from ASCE 7-22 as a design option. The technical language of the code amendment exactly duplicates the technical language of 7-22 to avoid differences. This change was first approved as an emergency code modification under IBC 2018, before becoming a standard code amendment under IBC 2021.

IBC 2024 now adopts ASCE 7-22 as a reference code, and the MPRS procedure is included directly. Because of this, the language of the previous code amendment should be deleted to avoid confusion due to duplicating the requirements in ASCE 7-22 and in the Washington State Building Code amendments. Further, the previous code amendment describes use of the MPRS as “an alternative” when ASCE 7-22 intends to make this procedure mandatory. To align with the intent of ASCE 7-22, language of the previous code amendment should be deleted from the Washington State Building Code amendments.

6. **Specify what criteria this proposal meets.** You may select more than one.

- ☐ The amendment is needed to address a critical life/safety need.
- ☒ The amendment clarifies the intent or application of the code.
- ☐ The amendment is needed to address a specific state policy or statute.
- ☒ The amendment is needed for consistency with state or federal regulations.
- ☐ The amendment is needed to address a unique character of the state.
- ☐ The amendment corrects errors and omissions.

7. **Is there an economic impact:** ☐ Yes ☒ No

If no, state reason:

The proposal is for the removal of a code amendment that is no longer needed when the state adopts the ASCE-7-22 standard. This will not increase or decrease the cost of construction.

If yes, provide economic impact, costs and benefits as noted below in items a – f.

- a. **Life Cycle Cost.** Use the OFM Life Cycle Cost [Analysis tool](#) to estimate the life cycle cost of the proposal using one or more typical examples. Reference these [Instructions](#); use these [Inputs](#). Webinars on the tool can be found [Here](#) and [Here](#)). If the tool is used, submit a copy of the excel file with your proposal submission. If preferred, you may submit an alternate life cycle cost analysis.
- b. **Construction Cost.** Provide your best estimate of the construction cost (or cost savings) of your code change proposal.

\$Varies/square foot

(For residential projects, also provide \$Click here to enter text./ dwelling unit)

Show calculations here, and list sources for costs/savings, or attach backup data pages

- c. ***Code Enforcement.*** List any code enforcement time for additional plan review or inspections that your proposal will require, in hours per permit application:
- d. ***Small Business Impact.*** Describe economic impacts to small businesses:
- e. ***Housing Affordability.*** Describe economic impacts on housing affordability:
- f. ***Other.*** Describe other qualitative cost and benefits to owners, to occupants, to the public, to the environment, and to other stakeholders that have not yet been discussed:

Please send your completed proposal to: sbcc@des.wa.gov

All questions must be answered to be considered complete. Incomplete proposals will not be accepted.