



STATE OF WASHINGTON
STATE BUILDING CODE COUNCIL

May 2018
Log No. _____

1. State Building Code to be Amended:

- | | |
|---|---|
| <input type="checkbox"/> International Building Code | <input type="checkbox"/> International Mechanical Code |
| <input type="checkbox"/> ICC ANSI A117.1 Accessibility Code | <input type="checkbox"/> International Fuel Gas Code |
| <input type="checkbox"/> International Existing Building Code | <input type="checkbox"/> NFPA 54 National Fuel Gas Code |
| <input type="checkbox"/> International Residential Code | <input type="checkbox"/> NFPA 58 Liquefied Petroleum Gas Code |
| <input checked="" type="checkbox"/> International Fire Code | <input type="checkbox"/> Wildland Urban Interface Code |
| <input type="checkbox"/> Uniform Plumbing Code | |

For the Washington State Energy Code, please see specialized [energy code forms](#)

Section(s): NEW 611

Title: ELECTRIC VEHICLE CHARGING STATIONS

2. Proponent Name (Specific local government, organization or individual):

Proponent: Ken Brouillette
Title: Technical Code Coordinator
Date: 9/6/2024

3. Designated Contact Person:

Name: Ken Brouillette
Title: Technical Code Coordinator
Address: 220 3rd Ave. S, Seattle WA 98104

Office Phone: (206)386-1455
Cell: ()
E-Mail address: ken.brouillette@seattle.gov

4. **Proposed Code Amendment.** Reproduce the section to be amended by underlining all added language, striking through all deleted language. Insert new sections in the appropriate place in the code in order to continue the established numbering system of the code. If more than one section is proposed for amendment or more than one page is needed for reproducing the affected section of the code, additional pages may be attached.

Clearly state if the proposal modifies an existing amendment or if a new amendment is needed. If the proposal modifies an **existing amendment**, show the modifications to the existing amendment by underlining all added language and striking through all deleted language. If a new amendment is needed, show the modifications to the **model code** by underlining all added language and striking through all deleted language.

Code(s) 2024 IFC Section(s) NEW 611

Enforceable code language must be used.
Add new section to read as follows:

SECTION 611
ELECTRIC VEHICLE CHARGING STATIONS

611.1 Disconnecting Means. Permanently connected electric vehicle supply equipment shall be provided with one or more emergency disconnects and shall be installed in accordance with NFPA 70.

5. **Briefly explain your proposed amendment, including the purpose, benefits and problems addressed.**

The requirements in the IFC should match NFPA 70 (NEC). This allows the fire code official to require the disconnecting means and the electrical code will be used to ensure installations are in compliance. We use the pointer and reference to NFPA 70 throughout the IFC for other items.

6. **Specify what criteria this proposal meets.** You may select more than one.

- The amendment is needed to address a critical life/safety need.
- The amendment clarifies the intent or application of the code.
- The amendment is needed to address a specific state policy or statute.
- The amendment is needed for consistency with state or federal regulations.
- The amendment is needed to address a unique character of the state.
- The amendment corrects errors and omissions.

7. **Is there an economic impact:** Yes No

If no, state reason: The change proposal points the user to NFPA 70 for the prescriptive installation requirements therefore the cost impact neither increases or decreases.

If yes, provide economic impact, costs and benefits as noted below in items a – f.

- a. **Life Cycle Cost.** Use the OFM Life Cycle Cost [Analysis tool](#) to estimate the life cycle cost of the proposal using one or more typical examples. Reference these [Instructions](#); use these [Inputs](#). Webinars on the tool can be found [Here](#) and [Here](#)). If the tool is used, submit a copy of the excel file with your proposal submission. If preferred, you may submit an alternate life cycle cost analysis.

- b. **Construction Cost.** Provide your best estimate of the construction cost (or cost savings) of your code change proposal.

\$Click here to enter text./square foot

(For residential projects, also provide \$Click here to enter text./ dwelling unit)

Show calculations here, and list sources for costs/savings, or attach backup data pages

- c. **Code Enforcement.** List any code enforcement time for additional plan review or inspections that your proposal will require, in hours per permit application:
- d. **Small Business Impact.** Describe economic impacts to small businesses:
- e. **Housing Affordability.** Describe economic impacts on housing affordability:
- f. **Other.** Describe other qualitative cost and benefits to owners, to occupants, to the public, to the environment, and to other stakeholders that have not yet been discussed:

Please send your completed proposal to: sbcc@des.wa.gov

All questions must be answered to be considered complete. Incomplete proposals will not be accepted.