



STATE OF WASHINGTON
STATE BUILDING CODE COUNCIL

May 2018
Log No. _____

1. State Building Code to be Amended:

- | | |
|---|---|
| <input type="checkbox"/> International Building Code | <input type="checkbox"/> International Mechanical Code |
| <input type="checkbox"/> ICC ANSI A117.1 Accessibility Code | <input type="checkbox"/> International Fuel Gas Code |
| <input type="checkbox"/> International Existing Building Code | <input type="checkbox"/> NFPA 54 National Fuel Gas Code |
| <input type="checkbox"/> International Residential Code | <input type="checkbox"/> NFPA 58 Liquefied Petroleum Gas Code |
| <input checked="" type="checkbox"/> International Fire Code | <input type="checkbox"/> Wildland Urban Interface Code |
| <input type="checkbox"/> Uniform Plumbing Code | |

For the Washington State Energy Code, please see specialized [energy code forms](#)

Section(s): 503

Title: FIRE APPARATUS ACCESS ROADS

2. Proponent Name (Specific local government, organization or individual):

Proponent: 2024 International Fire Code Technical Advisory Group

Title: Ricky Campbell

Date: 9/12/2024

3. Designated Contact Person:

Name: Ricky Campbell

Title:

Address:

Office Phone: ()

Cell: (206) 681-8406

E-Mail address: ricky@ualocal699.org

4. Proposed Code Amendment. Reproduce the section to be amended by underlining all added language, striking through all deleted language. Insert new sections in the appropriate place in the code in order to continue the established numbering system of the code. If more than one section is proposed for amendment or more than one page is needed for reproducing the affected section of the code, additional pages may be attached.

Clearly state if the proposal modifies an existing amendment or if a new amendment is needed. If the proposal modifies an **existing amendment**, show the modifications to the existing amendment by underlining all added language and striking through all deleted language. If a new amendment is needed, show the modifications to the **model code** by underlining all added language and striking through all deleted language.

Code(s) 2024 IFC **Section(s)** 503.1 – 503.4.1

Enforceable code language must be used.

Amend section to read as follows:

503.1 Where required. Fire apparatus access roads shall be provided and maintained in accordance with Sections 503.1.1 through 503.1.3, locally adopted street, road, and access standards.

~~**503.1.1 Buildings and facilities.** Approved fire apparatus access roads shall be provided for every facility, building or portion of a building hereafter constructed or moved into or within the jurisdiction. The fire apparatus access road shall comply with the requirements of this section and shall extend to within 150 feet (45 720 mm) of all portions of the facility and all portions of the exterior walls of the first story of the building as measured by an approved route around the exterior of the building or facility.~~

Exceptions:

1. ~~The fire code official is authorized to increase the dimension of 150 feet (45 720 mm) where any of the following conditions occur:~~

1.1. ~~The building is equipped throughout with an approved automatic sprinkler system installed in accordance with Section 903.3.1.1, 903.3.1.2 or 903.3.1.3.~~

1.2. ~~Fire apparatus access roads cannot be installed because of location on property, topography, waterways, nonnegotiable grades or other similar conditions, and an approved alternative means of fire protection is provided.~~

1.3. ~~There are not more than two Group R-3 or Group U occupancies.~~

2. ~~Where approved by the fire code official, fire apparatus access roads shall be permitted to be exempted or modified for solar photovoltaic power generation facilities.~~

~~503.1.2 Additional access. The fire code official is authorized to require more than one fire apparatus access road based on the potential for impairment of a single road by vehicle congestion, condition of terrain, climatic conditions or other factors that could limit access.~~

~~503.1.3 High piled storage. Fire department vehicle access to buildings used for high piled combustible storage shall comply with the applicable provisions of Chapter 32.~~

~~503.2 Specifications. Fire apparatus access roads shall be installed and arranged in accordance with Sections 503.2.1 through 503.2.8.~~

~~503.2.1 Dimensions. Fire apparatus access roads shall have an unobstructed width of not less than 20 feet (6096 mm), exclusive of shoulders, except for approved security gates in accordance with Section 503.6, and an unobstructed vertical clearance of not less than 13 feet 6 inches (4115 mm).~~

~~503.2.2 Authority. The fire code official shall have the authority to require or permit modifications to the required access widths where they are inadequate for fire or rescue operations or where necessary to meet the public safety objectives of the jurisdiction.~~

~~503.2.3 Surface. Fire apparatus access roads shall be designed and maintained to support the imposed loads of fire apparatus and shall be surfaced so as to provide all-weather driving capabilities.~~

~~503.2.4 Turning radius. The required turning radius of a fire apparatus access road shall be determined by the fire code official.~~

~~503.2.5 Dead ends. Dead-end fire apparatus access roads in excess of 150 feet (45 720 mm) in length shall be provided with an approved area for turning around fire apparatus.~~

~~503.2.6 Bridges and elevated surfaces. Where a bridge or an elevated surface is part of a fire apparatus access road, the bridge shall be constructed and maintained in accordance with AASHTO HB-17. Bridges and elevated surfaces shall be designed for a live load sufficient to carry the imposed loads of fire apparatus. Vehicle load limits shall be posted at both entrances to bridges where required by the fire code official. Where elevated surfaces designed for emergency vehicle use are adjacent to surfaces that are not designed for such use, approved barriers, approved signs or both shall be installed and maintained where required by the fire code official.~~

~~503.2.7 Grade. The grade of the fire apparatus access road shall be within the limits established by the fire code official based on the fire department's apparatus.~~

~~503.2.8 Angles of approach and departure. The angles of approach and departure for fire apparatus access roads shall be within the limits established by the fire code official based on the fire department's apparatus.~~

~~503.3 Marking. Where required by the fire code official, approved signs or other approved notices or markings that include the words "NO PARKING—FIRE LANE" shall be provided for fire apparatus access roads to identify such roads or prohibit the obstruction thereof. The means by which fire lanes are designated shall be maintained in a clean and legible condition at all times and be replaced or repaired when necessary to provide adequate visibility.~~

~~503.4 Obstruction of fire apparatus access roads. Fire apparatus access roads shall not be obstructed in any manner, including the parking of vehicles. The minimum widths and clearances established in Sections 503.2.1 and 503.2.2 shall be maintained at all times.~~

~~503.4.1 Traffic calming devices. Traffic calming devices shall be prohibited unless approved by the fire code official.~~

5. Briefly explain your proposed amendment, including the purpose, benefits and problems addressed. Specifically note any impacts or benefits to business, and specify construction types, industries and services

that would be affected. Finally, please note any potential impact on enforcement such as special reporting requirements or additional inspections required.

503.1 Where required. - Keep state amendment WAC 51-54A-0503

503.1.1 Buildings and facilities. This section is not adopted. WAC 51-54A-0503

503.1.2 Additional access. This section is not adopted. WAC 51-54A-0503

503.1.3 High-piled storage. This section is not adopted. WAC 51-54A-0503

503.2 Specifications. This section is not adopted. WAC 51-54A-0503

503.3 Marking. This section is not adopted. WAC 51-54A-0503

503.4 Obstruction of fire apparatus access roads. This section is not adopted. WAC 51-54A-0503

503.4.1 Traffic calming devices. This section is not adopted. WAC 51-54A-0503

6. **Specify what criteria this proposal meets.** You may select more than one.

- The amendment is needed to address a critical life/safety need.
- The amendment clarifies the intent or application of the code.
- The amendment is needed to address a specific state policy or statute.
- The amendment is needed for consistency with state or federal regulations.
- The amendment is needed to address a unique character of the state.
- The amendment corrects errors and omissions.

7. **Is there an economic impact:** Yes No

If no, state reason:

The code change proposal will not increase or decrease the cost of construction.

The intent is to provide additional design flexibility and equivalency.

If yes, provide economic impact, costs and benefits as noted below in items a – f.

a. **Life Cycle Cost.** Use the OFM Life Cycle Cost [Analysis tool](#) to estimate the life cycle cost of the proposal using one or more typical examples. Reference these [Instructions](#); use these [Inputs](#). Webinars on the tool can be found [Here](#) and [Here](#)). If the tool is used, submit a copy of the excel file with your proposal submission. If preferred, you may submit an alternate life cycle cost analysis.

b. **Construction Cost.** Provide your best estimate of the construction cost (or cost savings) of your code change proposal.

\$[Click here to enter text.](#)/square foot

(For residential projects, also provide \$[Click here to enter text.](#)/ dwelling unit)

Show calculations here, and list sources for costs/savings, or attach backup data pages

c. **Code Enforcement.** List any code enforcement time for additional plan review or inspections that your proposal will require, in hours per permit application:

d. **Small Business Impact.** Describe economic impacts to small businesses:

e. **Housing Affordability.** Describe economic impacts on housing affordability:

- f. ***Other.*** Describe other qualitative cost and benefits to owners, to occupants, to the public, to the environment, and to other stakeholders that have not yet been discussed:

Please send your completed proposal to: sbcc@des.wa.gov

All questions must be answered to be considered complete. Incomplete proposals will not be accepted.