



STATE OF WASHINGTON  
**STATE BUILDING CODE COUNCIL**

May 2018  
Log No. \_\_\_\_\_

**1. State Building Code to be Amended:**

- International Building Code
- ICC ANSI A117.1 Accessibility Code
- International Existing Building Code
- International Residential Code
- International Fire Code
- Uniform Plumbing Code

- International Mechanical Code
- International Fuel Gas Code
- NFPA 54 National Fuel Gas Code
- NFPA 58 Liquefied Petroleum Gas Code
- Wildland Urban Interface Code

For the Washington State Energy Code, please see specialized [energy code forms](#)

**Section(s):**

(e.g.: Section: R403.2)

Section 429

**Title:**

(e.g: Footings for wood foundations)

Electric vehicle charging infrastructure

**2. Proponent Name (Specific local government, organization or individual):**

**Proponent:** Ross Freeman

**Title:** EV Program Mgr, King County Executive Climate Office

**Date:** September 19, 2024

**3. Designated Contact Person:**

**Name:** Kathleen Petrie

**Title:** Green Building Program Mgr, King County

**Address:** 201 S. Jackson St, Suite 5701, Seattle WA 98104

**Office Phone:** (206) 477-2482

**Cell:** ( )

**E-Mail address:** kpetrie@kingcounty.gov

**4. Proposed Code Amendment.** Reproduce the section to be amended by underlining all added language, striking through all deleted language. Insert new sections in the appropriate place in the code in order to continue the established numbering system of the code. If more than one section is proposed for amendment or more than one page is needed for reproducing the affected section of the code, additional pages may be attached.

Clearly state if the proposal modifies an existing amendment or if a new amendment is needed. If the proposal modifies an **existing amendment**, show the modifications to the existing amendment by underlining all added language and striking through all deleted language. If a new amendment is needed, show the modifications to the **model code** by underlining all added language and striking through all deleted language.

Code(s) \_\_\_\_\_ International Building Code \_\_\_\_\_ Section(s) \_\_\_\_\_ 429 \_\_\_\_\_

Enforceable code language must be used.

Amend section to read as follows:

**429.1 General.** The provisions of this section shall apply to the construction of new buildings and accessory structures, including parking lots and parking garages.

Electric vehicle supply equipment (EVSE) shall be installed in accordance with applicable requirements of chapter 19.28 RCW and the National Electrical Code, Article 625.

**EXCEPTION:** Electric vehicle charging infrastructure is not required if any of the following conditions are met:

1. There is no public utility or commercial power supply.
2. Dwelling units without garages or other on-site parking.

**429.2 Electric vehicle (EV) charging infrastructure.** Buildings and accessory structures shall be provided with EV charging stations, EV-Ready parking spaces, and EV-capable parking spaces in accordance with Table 429.2. Calculations shall be rounded up to the nearest whole number. Where a building contains more than one occupancy, the electric vehicle charging infrastructure percentages of Table 429.2 shall be applied to the number of spaces required for each occupancy.

**EXCEPTIONS:**

1. Except for Group A, Group E, and Group M occupancies, on-site parking with less than 10 parking spaces shall not be required to comply with Section 429.2.
2. Group A, Group E, and Group M occupancies shall comply with one of the following, whichever is greater:
  - 2.1. The provisions of Section 429.2 shall apply only to designated employee parking spaces.
  - 2.2. One of each 200 parking spaces or fraction thereof shall be EV Ready. One of each 200 parking spaces or fraction thereof shall be an EV Charging Station.

**Table 429.2 Electric Vehicle Charging Infrastructure**

Occupancy	Number of EV Charging Stations	Number of EV-Ready Parking Spaces	Number of EV-Capable Parking Spaces
Group A, B, E, F, H, I, M, and S Occupancies	10% of total parking spaces	10% of total parking spaces	10% of total parking spaces
Group R Occupancies			
Buildings that do not contain more than two dwelling units	Not required	One for each dwelling unit	Not required

Dwelling units with private garages	Not required	One for each dwelling unit	Not required
All other Group R occupancies	10% of total parking spaces	<del>40%</del> 25% of total parking spaces	10% of total parking spaces

\*\*\*

- 5. Briefly explain your proposed amendment, including the purpose, benefits and problems addressed.** Specifically note any impacts or benefits to business, and specify construction types, industries and services that would be affected. Finally, please note any potential impact on enforcement such as special reporting requirements or additional inspections required.

**Reason for Proposed Code Modifications:**

- A unique character (criteria point) of Washington is that we are a Zero-emission Vehicle state (ZEV). Washington [Senate Bill 5811](#), the Motor Vehicles Emissions Law, directs the state Department of Ecology to adopt California’s emissions standards; [California’s Zero-emission vehicle requirements within ACC II](#) requires all new vehicles to reach 100% zero-emission and clean plug-in hybrid-electric in California by the 2035 model; thereby precluding the sale of new combustion engine vehicles. Preparing our new and existing buildings now with an increase in EV-Ready spaces will help to create necessary infrastructure.
- Federal studies estimate that about 70-80% of charging today occurs at home, because it allows access to the cheapest rates and is the most convenient, typically accomplished overnight. Therefore, codes that accelerate this access, especially for residents of multi-family buildings, will be critical to developing sufficient charging infrastructure.
- Current totals are not on track to achieve these targets. According to the federal [Alternative Fuels Data Center](#), Washington has only 4,501 public L2 ports statewide available today. And although there is no reliable published count of non-public residential chargers in WA, if we assume that approximately 70% of the state’s 152,000 EVs currently registered have access to home charging, that equates to only 105,000 ports in residential settings.
- [California code](#) currently requires 10% EV-installed chargers and 40% EV-ready stalls. If Washington is modeling California’s Zero Emission requirements, then then it is pertinent to modify Washington’s Building Code EV-ready infrastructure requirements to reflect 40%, as well.
- City-specific ordinances in [San Jose](#), [Chicago](#), and [Vancouver BC](#) push further to require 90%-100% of EV-ready spaces in multifamily buildings.

- 6. Specify what criteria this proposal meets.** You may select more than one.

- The amendment is needed to address a critical life/safety need.
- The amendment clarifies the intent or application of the code.
- The amendment is needed to address a specific state policy or statute.
- The amendment is needed for consistency with state or federal regulations.
- The amendment is needed to address a unique character of the state.
- The amendment corrects errors and omissions.

- 7. Is there an economic impact:**  Yes  No

If no, state reason:

If yes, provide economic impact, costs and benefits as noted below in items a – f.

- a. **Life Cycle Cost.** Use the OFM Life Cycle Cost [Analysis tool](#) to estimate the life cycle cost of the proposal using one or more typical examples. Reference these [Instructions](#); use these [Inputs](#). Webinars on the tool can be found [Here](#) and [Here](#)). If the tool is used, submit a copy of the excel file with your proposal submission. If preferred, you may submit an alternate life cycle cost analysis.
- b. **Construction Cost.** Provide your best estimate of the construction cost (or cost savings) of your code change proposal.

\$Click here to enter text./square foot

(For residential projects, also provide \$Click here to enter text./ dwelling unit)

Show calculations here, and list sources for costs/savings, or attach backup data pages

#### **Funding/Incentives available:**

- The State Department of Commerce is taking the apparent deficit of chargers seriously, especially in the case of public and multi-family settings. As of August 2024, its [EV Charging Program](#) has awarded \$54 million for 792 new public chargers and \$28 million for 3,118 new multi-family chargers. Non-profit organizations and affordable housing providers were eligible to apply for funds, and many did: 97 of the 200 multi-family sites funded for L2 charging are also located in overburdened areas. Future rounds of funding in this new program are anticipated.
- Other sources of funding available to housing providers include the federal [Charging and Fueling Infrastructure](#) grant program, which now allows proposals not only along travel corridors, but also on commercial property, and even in gated private parking areas as long as there is public access.
- Some power utilities in Washington also offer generous rebate funding for multi-family property owners to install EV charging, and often will cover 100% of retrofit costs for properties where approximately half of residents are low-income or Tribal residents; for example Puget Sound Energy's [Empower Mobility incentives](#), and Seattle City Light's [Multifamily EV Charging Program](#).
- All this available funding helps to offset costs (below).

#### **Costs:**

- Average costs to retrofit a new 2-port Level 2 charger vary depending on the features, network connections, and range of payment options accepted, as well as the distance to a suitable existing power supply and amount of trenching involved (if any). In the best case, for simpler installation scenarios, \$15,000 is a reasonable ballpark figure to install one such 2-port networked charger, and this aligns with the per-port rebate caps offered by PSE and SCL.
- It is also important to note that load management software can reduce a retrofit's implementation costs up to 60% by avoiding the need for circuit and panel upgrades. These systems, often built into modern chargers, determine how much power to allocate among all active ports based on the number of vehicles plugged in at a given time, how "empty" they are, and the pre-set limits of the main power supply. This can be set up in a number of ways, as discussed in [this article](#).
- In general, however, retrofit installations of EV chargers into existing buildings and parking lots costs much more than planning and executing this work during the construction phase. After 5 years under California's stricter EV infrastructure building codes, a 2019 study found that each EV-capable parking space installed in a multi-family dwelling during new construction saved \$2,040-4,635 over the retrofit scenario – given today's post-COVID increases in equipment and labor costs, this delta is assumed to be even greater. Research for Denver's [2022 EV Readiness ordinance](#)

provides additional insight into the average estimated costs for EV-capable and EV-ready parking spaces installed during new construction, as compared to retrofits. An EV-capable stall costs \$300 during new construction vs. \$2,500 during retrofit, while a full EV-ready stall costs \$1,300 during new construction vs. \$6,300 during retrofit.

- c. **Code Enforcement.** List any code enforcement time for additional plan review or inspections that your proposal will require, in hours per permit application:
  - No anticipated impacts to staff.
- d. **Small Business Impact.** Describe economic impacts to small businesses:
  - None.
- e. **Housing Affordability.** Describe economic impacts on housing affordability:
  - Per the Funding/Incentives information provided in the “Construction Costs” section of this document, there are many avenues of funding support to help mitigate the impacts of added infrastructure
    - Although the cost information shares that an EV-Ready infrastructure costs \$1,300 per parking space, the Funding/Incentives information provided in the “Construction Costs” section also identifies incentives available to offset these costs for new construction and retrofits.
- f. **Other.** Describe other qualitative cost and benefits to owners, to occupants, to the public, to the environment, and to other stakeholders that have not yet been discussed:
  - Renters are dependent on the amenities provided by the building developer or owner. Requiring infrastructure ensures an EV owner is not limited in housing because their apartment does not have charging capabilities; nor does it force a renter to purchase a combustion engine vehicle because their existing building does not have charging capabilities.

Please send your completed proposal to: [sbcc@des.wa.gov](mailto:sbcc@des.wa.gov)

**All questions must be answered to be considered complete. Incomplete proposals will not be accepted.**