



# Washington State Building Code Council

*Improving the built environment by promoting health, safety and welfare*

1500 Jefferson Street SE • P.O. Box 41449 • Olympia, Washington 98504  
(360) 407-9277 • e-mail [sbcc@des.wa.gov](mailto:sbcc@des.wa.gov) • [www.sbcc.wa.gov](http://www.sbcc.wa.gov)

## STATE BUILDING CODE OPINION NO. 24-32

**CODE:** 2021 Washington State Energy Code—Commercial

**SECTION:** C401.3 / C503.1 Building Mechanical Alterations

**QUESTION:** For a mechanical alteration complying under the C401.3 fossil fuel compliance path, is the total required number of additional energy credits limited to the number required by Table C401.3.3?

**ANSWER:** **Yes. Per Section C503.1, the additional energy efficiency requirements in Section C406.1 do not apply to mechanical alterations.**

**SUPERSEDES:** None

**REQUESTED BY:** King County