



STATE OF WASHINGTON

STATE BUILDING CODE COUNCIL

2015 Washington State Energy Code Development Energy Code Proposal Short Form

For editorial **Coordination, Clarifications & Corrections** only,
without substantive energy or cost impacts

May 2025

Log No. 24-GP1-184

Revision 2 May 1, 2025

Code being amended: ☒ Commercial Provisions ☐ Residential Provisions
(A MS Word version of the code is linked to the name)

Code Section # C402.4 Fenestration

Brief Description **Rev 2:**

- Add exception for security glazing ~~and revolving doors~~
- ~~Clarify meaning of "operable."~~
- ~~Add informative note to clarify fenestration categories.~~

Revision description: Delete revolving doors from proposed exception, since there are currently many double-pane products on the market.

Proposed code change text:

C402.4 Fenestration. Fenestration shall comply with Sections C402.4.1 through C402.4.5 and Table C402.4. Daylight responsive controls shall comply with this section and Section C405.2.4.

Exception: For prescriptive envelope compliance, single-pane glazing is permitted for security purposes ~~and for revolving doors~~, not to exceed 1 percent of the gross exterior wall area. Where Section C402.1.5, component performance alternative, is used, the single glazing shall be included in the percentage of the total glazing area, U-factor and SHGC requirements.

Purpose of code change: Clarifies application of code to security glazing.

Clarifies application of code for small areas of single glazing for which code compliance is difficult.

Your name Duane Jonlin

Other contact name [Click here to enter text.](#)

Your organization Seattle Department of
Construction and Inspections

Email address duane.jonlin@seattle.gov

Phone number 206-233-2781