

STATE BUILDING CODE COUNCIL

Washington State Energy Code Development Standard Energy Code Proposal Form

Coordination of 144, 146, 147, and 166 L. Rosenow 6/09/25

Code being amended: Commercial Provisions Residential Provisions

Code Section # C406.1, C410.1, C410.3, C410.4 and C405.1

Brief Description:

Combination of all proposed changes from 24-GP1-144, 146, 147 and 166.

Proposed code change text: (Copy the existing text from the Integrated Draft, linked above, and then use <u>underline</u> for new text and <u>strikeout</u> for text to be deleted.)

ROSENOW 24-GP1-144 (AS TAG AMENDED) AND ROSENOW 24-GP1-147 (AS TAG AMENDED)

C406.1 Additional energy efficiency and load management measures credit requirements. The project as defined in the building permit shall meet the following requirements as applicable:

- New buildings, changes in space conditioning category, change of occupancy group, and building additions in accordance with Chapter 5 shall comply with sufficient measures from Section C406.2 so as to achieve the minimum number required efficiency credits shown in Table C406.1.
- 2. New buildings greater than 5000 gross square feet of floor area shall comply with sufficient measures from Section C406.3 so as to achieve the minimum number of required load management credits shown in Table C406.1.
- 3. Tenant spaces shall comply in accordance with Section C406.1.1.
- 4. Projects using discrete area credit weighting shall comply in accordance with Section C406.1.2.

Exceptions:

- Low energy spaces in accordance with Section C402.1.1.1, equipment buildings in accordance with Section C402.1.2, refrigerated warehouse cooler and freezer spaces in accordance with Section C410, unconditioned spaces, open parking garages, and enclosed parking garages that comply with sufficient measures from Table C406.2(1) to achieve a minimum of 50 percent of the efficiency credits required for new construction. Such projects shall be exempt from the load management requirements in Table C406.1.
- Building additions that have less than 1,000 square feet of conditioned floor area that comply with sufficient
 measures from Table C406.2(1) to achieve a minimum of 50 percent of the efficiency credits required for
 additions.
- Warehouses, including refrigerated warehouse cooler and freezer spaces in accordance with Section C410, are
 exempt from the load management credit requirements in Table C406.1. COMMENT This 24-GP1-144 edit is
 no longer needed per edit to Item 1 from 24-GP1-147 above.

ROSENOW 24-GP1-144 (AS TAG AMENDED) AND JONLIN 24-GP1-166

C410.1 General. Walk in coolers, walk in freezers, refrigerated warehouse coolers, refrigerated warehouse freezers, and refrigerated display cases shall comply with this Section. Spaces that are served by refrigeration systems including walk-in coolers, walk-in freezers, refrigerated warehouse coolers, and refrigerated warehouse freezers, and refrigerated display cases, shall comply with this Section. Where the envelope assemblies of these spaces comprise any portion of

Commented [JD1]: could delete this "and"

June 9, 2025

the *building thermal envelope*, these assemblies shall also comply with all applicable requirements of Section C402, substituting the R-values or U-factors required by Section C410.3.

Whole buildings and portions of buildings that are refrigerated warehouse cooler or freezer spaces shall also comply with Sections C406 and C411. Refrigerated warehouse cooler and freezer spaces that are fully enclosed within the building interior of a conditioned, semi-heated or low energy space shall use apply the space type of the building they are in which they are located to for the requirements in Sections C406 and C411.

ROSENOW 24-GP1-144 (AS TAG AMENDED) AND ROSENOW 24-GP1-146

C410.3 Walk-in coolers, walk-in freezers, refrigerated warehouse coolers and refrigerated warehouse freezers. Site-assembled and site-constructed walk-in coolers_((and)) walk-in freezers_((and)) refrigerated warehouse coolers, and refrigerated warehouse freezers shall comply with the following:

- Automatic door-closers shall be provided that fully close walk-in doors that have been closed to within 1 inch (25 mm) of full closure.
 - **Exception:** Automatic closers are not required for doors more than 45 inches (1143 mm) in width or more than 7 feet (2134 mm) in height.
- 2. Doorways shall be provided with strip doors, curtains, spring-hinged doors or other method of minimizing infiltration when doors are open.
- 3. Walk-in coolers and refrigerated warehouse coolers shall be provided with wall, ceiling, and door insulation of not less than R-25 or have wall, ceiling and door assembly *U*-factors no greater than <u>U</u>0.039. Walk-in freezers and refrigerated warehouse freezers shall be provided with wall, ceiling and door insulation of not less than R-32 or have wall, ceiling and door assembly *U*-factors no greater than <u>U</u>0.030.
 - **Exception:** Insulation is not required for glazed portions of doors or at structural members associated with the walls, ceiling or door frame.
- 4. The floor of walk-in coolers and refrigerated warehouse coolers shall be provided with floor insulation of not less than R-25 or have a floor assembly *U*-factor no greater than <u>U</u>-0.40. The floor of walk-in freezers and refrigerated warehouse freezers shall be provided with floor insulation of not less than R-28 or have a floor assembly *U*-factor no greater than <u>U</u>-0.035.
 - **Exception:** Insulation is not required in the floor of a *walk-in cooler* or refrigerated warehouse cooler that is mounted directly on a slab on grade floor.
- Transparent fixed window and reach-in doors for walk-in freezers and windows in walk-in freezer doors shall be
 provided with triple-pane glass, with the interstitial spaces filled with inert gas or be provided with heat-reflective
 treated glass.
- 6. Transparent fixed window and reach-in doors for *walk-in coolers* and windows for *walk-in coolers* doors shall be provided with double-pane or triple-pane glass, with interstitial space filled with inert gas, or be provided with heat-reflective treated glass.
- Envelope assembly elements not governed by this section, including but not limited to glazed windows and doors
 separating walk-in and warehouse cooler spaces from conditioned space and perimeter slab edge insulation, shall
 comply with the thermal envelope requirements in Section C402.
- 8. Evaporator fan motors that are less than 1 hp (0.746 kW) and less than 460 volts shall be provided with electronically commutated motors, brushless direct-current motors, or 3-phase motors.
- 9. Condenser fan motors that are less than 1 hp (0.746 kW) shall use electronically commutated motors, permanent split capacitor-type motors or 3-phase motors.
- 10. Antisweat heaters that are not provided with antisweat heater controls shall have a total door rail, glass and frame heater power draw of not greater than 7.1 W/ft² (76 W/m²) of door opening for walk-in freezers and not greater than 3.0 W/ft² (32 W/m²) of door opening for walk-in coolers.
- 11. Where antisweat heater controls are provided, they shall be capable of reducing the energy use of the antisweat heater as a function of the relative humidity in the air outside the door or to the condensation on the inner glass pane.

12. Lights in walk-in coolers, walk-in freezers, refrigerated warehouse coolers and refrigerated warehouse freezers shall either be provided with light sources with an efficacy of not less than 40 lumens per watt, including ballast losses, or shall be provided with a device that automatically turns off the lights within 15 minutes of when the walk-in cooler or walk-in freezer space is not occupied.

C410.4 Refrigerated case and walk-in display door((s)) <u>lighting.</u> Lighting in glass doors in all *walk-in coolers* and *walk-in freezers* and all *refrigerated warehouse coolers* and *refrigerated warehouse freezers* shall comply with the following:

- 1. Time switch controls to turn off lights during nonbusiness hours. Timed overrides for display cases shall turn the lights on for up to 1 hour and shall automatically time out to turn the lights off.
- 2. Motion sensor controls on each display case section that reduce lighting power by at least 50 percent within 3 minutes after the area within the sensor range is vacated.

C410.6 Commissioning. Refrigeration systems shall be commissioned in accordance with Section C408. **Exception**: Self-contained units.

C410.7 Energy metering. Refrigeration systems shall comply with the energy metering requirements in Section C409.

ROSENOW 24-GP1-146 - SECTION REFERENCE CORRECTION

Other contact name Click here to enter text.

C405.1 General. Electrical power and lighting systems and power generation shall comply with this section.

General lighting shall consist of all lighting included when calculating the total connected interior lighting power in accordance with Section C405.4.1 and which does not require specific application controls in accordance with Section C405.2.5

Lighting installed in walk-in coolers, walk-in freezers, refrigerated warehouse coolers and refrigerated warehouse freezers shall comply with the lighting requirements of Sections C410.2 C410.3 and C410.4.

Purpose of code cha	nge:				
Clarify code intent for	or refrigerated spaces	s.			
Your amendment must meet one of the following criteria. Select at least one:					
Addresses a critical life/safety need.			Consistency with state or federal regulations.		
 ☑ The amendment clarifies the intent or application of the code. ☑ Addresses a specific state policy or statute. (Note that energy conservation is a state policy) 			Addresses a unique character of the state. Corrects errors and omissions.		
Check the building ty	/pes that would be im	pacted by your code o	change:		
Single family/duplex/townhome		Multi-family 4 + stories			
Multi-family 1 − 3 stories		Commercial / Retail		 Industrial	
Your name	Lisa Rosenow		Email address	Irosenow@evergreen-tech.net	
Your organization Evergreen Technology Consulting		Phone number	360-539-5202		

Economic Impact Data Sheet				
Is there an economic impact: Yes No				
Briefly summarize your proposal's primary economic impacts and benefits to building owners, tenants, and businesses. If you answered "No" above, explain your reasoning.				
This is a clarifying proposal based on draft SBCC official opinions. It does not add a new prescriptive or mandatory requirement or associated costs.				
Provide your best estimate of the construction cost (or cost savings) of your code change proposal? (See OFM Life Cycle Cost <u>Analysis tool</u> and <u>Instructions;</u> use these <u>Inputs</u> . Webinars on the tool can be found <u>Here</u> and <u>Here</u>)				
\$Click here to enter text./square foot (For residential projects, also provide \$Click here to enter text./ dwelling unit)				
Show calculations here, and list sources for costs/savings, or attach backup data pages				
Provide your best estimate of the annual energy savings (or additional energy use) for your code change proposal?				
Click here to enter text.KWH/ square foot (or) Click here to enter text.KBTU/ square foot				
(For residential projects, also provide Click here to enter text.KWH/KBTU / dwelling unit)				
Show calculations here, and list sources for energy savings estimates, or attach backup data pages				
List any code enforcement time for additional plan review or inspections that your proposal will require, in hours per permit application:				
Does not change the scope of requirements that require plan review verification or inspection.				
Small Business Impact. Describe economic impacts to small businesses: No change.				
Housing Affordability. Describe economic impacts on housing affordability: No change.				
Other. Describe other qualitative cost and benefits to owners, to occupants, to the public, to the environment, and to other stakeholders that have not yet been discussed: NA				