DWELLING UNIT SIZE TOPIC SUMMARY

x	Date Scheduled	Date Discussed	Topic	NHHS Location	Washington Building Code	Comments
1	3/12/26		Review State Amendment	NA	Section 1208	Does not meet legislation reqs
2	3/12/26		Dwelling Unit Definition Update	Definitions Pg 23	Section 202	No proposed Change
3	3/12/26		Efficiency Dwelling Unit Definition		Section 202	Existing Amendment. No proposed Change
4	3/12/26		Habitable Space Definition Update	Definitions Pg 24	Section 202	No proposed Change
5	3/12/26		Accessibility	Section 2.5 Stretch Provisions	Chapter 11	No proposed Change
6	3/12/26		Miniumum Room Width	NA	1208.1	Proposed: reduce kitchen clear passageway to 30" from 36"
7	3/12/26		Minimum Ceiling Height	Section 2.6.5 7ft	1208.2	Habitable 7'6", Other areas 7', +exceptions. No proposed changes
8	3/12/26		Dwelling Unit Size	NA	1208.3	Must be reduced below 190sqft. Proposed: Change to Dwelling Unit Area. One room =120sqft.
9	3/12/26		Minimum Habitable Space	Section 2.6.3 70 sqft	1208.3	
10	3/12/26		Room Area	Section 2.6.3 70 sqft	1208.4	Proposed: Combine with 1208.3 Dwelling Unit Area
11	3/12/26		How many rooms needed?	NA	Silent	
12	3/12/26		Efficiency Dwelling Units	NA	1208.5	Proposed: Remove Section
13	3/12/26		Referenced Standards applicable?	NA	Silent	
14	3/12/26		Relevant difference between reduced size dwelling units and sleeping units	NA	NA	
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						

DWELLING UNIT SIZE TOPIC SUMMARY

28						
29						
30						
31						
32						